



SR 520 Bridge Replacement and HOV Program
 SR 520/I-5 Express Lanes Connection Project



SR520 I5 Mercer Street to SR520 Portage Bay - I5 Interchange Improvements
Major Public Projects Construction Noise Variance #6733975-NV

Noise Monitoring Weekly Report Summary for **Monday, June 26, 2023** to **Sunday, July 2, 2023**

PUBLISHED July 5, 2023

Monitoring times: Weekdays, 10 p.m. to 7 a.m.; weekends, 10 p.m. to 9 a.m.

How to use this report: This document summarizes the weekly nighttime noise data for the SR520 I5 Mercer Street to SR520 Portage Bay - I5 Interchange Improvements Project. In it, you'll find:

- Page 1 - Summary of noise levels recorded above the limits allowed under the Major Public Project Construction Noise Variance, for this week and throughout the project. This includes non-project-related noise exceedances
- Page 2 - Map of the project limits and locations of the five stationary monitor locations
- Pages 3 – 9 - Night-by-night noise recordings for each of the project noise monitors, along with a description of the work that night, comments received from the public regarding Project noise, and explanations for any noise limit exceedances and actions taken in response
- Page 10 - Log of public comments regarding nighttime noise issues and resolutions for the week


WSDOT is sharing this information as per the terms of the Major Public Project Construction Noise Variance (Permit #6733975).

MPPCNV start date: **Tuesday, August 23, 2022**
 MPPCNV days to date: **314**

WEEKLY TOTALS	
Nights worked this week (under the MPPCNV)	5
Public nighttime noise issue comments to project	0
Project related exceedances this week	0
Other Project-related non-compliance events this week	0
Non-project-related noise exceedances this week	119

PROJECT TOTALS TO DATE	
Total Nights Worked	354
Total public noise issue comments to project	15
Total Project related exceedances	28
Total Other Project related non-compliance events	14
Total non-project related exceedances	10608

MPPCNV Construction Noise Monitoring Locations

 Monitor Location
 Actual location may vary depending on construction work.
 See MPPCNV Decision and Application

Site M1 

Site M2 

Site M4 

Site M5 

Site M6 

MPPCNV Noise Monitoring Compliance Limits

Site	Leq	L1
M1	72	82
M2	74	84
M4	70	80
M5	71	81
M6	66	76



Sources: Esri, HERE, Garmin, USGS, Intermap, INCREMENT P, NRCan, Esri Japan, METI, Esri China (Hong Kong), Esri Korea, Esri (Thailand), NGCC, © OpenStreetMap contributors, and the GIS User Community

**SR520 I5 Mercer Street to SR520 Portage Bay - I5 Interchange Improvements
Major Public Project Construction Noise Variance - #6733975-NV**

NOISE MONITORING - WEEKLY REPORT

Monday, June 26, 2023 to Sunday, July 2, 2023 10 pm to 7 am (weekdays)/ 9am (weekends)

The table below includes data gathered from noise monitoring equipment in the Project area

Monday, June 26, 2023												
Site	Site limit (dBA)	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am
M1 - 624 Yale Ave N	1 Hr Leq	72	71.33	72.24	67.66	64.9	66.92	65.22	69.97	70.98	73.7	N/A
	1 Hr L1	82	74.9	73.9	71.9	68.5	71.5	67.9	70.7	74.9	76.6	N/A
M2 - 1547 Boylston Ave E	1 Hr Leq	74	75.07	73.85	71.11	70.57	70.63	71.39	74.21	77.49	78.36	N/A
	1 Hr L1	84	76.9	75.6	74.8	73.6	73.9	75.2	77.5	79.6	80	N/A
M4 - 3625 Federal Ave E	1 Hr Leq	70	61.41	59.4	57.27	54.21	53.52	52.54	56.93	61.53	63.47	N/A
	1 Hr L1	80	63.6	61.6	59.9	57.7	56.9	56.3	60.1	64	65.2	N/A
M5 - E Roanoke St & 10th Ave E	1 Hr Leq	71	62.99	60.71	59.08	56.29	55.24	58.95	58.78	63.55	66.29	N/A
	1 Hr L1	81	65.6	63.5	62.2	59.4	58.5	58.5	62	66.1	68.4	N/A
M6 - 3125 Eastlake Ave E	1 Hr Leq	66	75.47	67.78	60.81	59.5	61.69	60.42	63.35	78.55	80.08	N/A
	1 Hr L1	76	79.1	71.2	63.7	62.9	64.5	63.9	66	81.6	82.4	N/A
Mobile - 2411 Boylston Ave E	1 Hr Leq	71	71.62	69.7	68.15	66.7	67.12	67.97	70.4	73.31	74.46	N/A
	1 Hr L1	81	73.2	71.6	70.2	69.1	69.1	70.3	72.8	75	75.9	N/A

Notes recorded by the on-site Independent Noise Monitor

Work:

Walsh, Valley, Transcon and Trenchless were on site between 10:30pm and 3:30 am working on ramp meter, camera installation, installing wall panels, excavating, boring for loop junction boxes.

Public Comments:

None.

Exceedances:

Sites M1, M2, M6 & Mobile exceedances are not project related. Exceedances are caused by public traffic driving by the noise monitors.

Non-Compliance Events:

None.

Legend

N/A = Time Period not applicable to MPPCNV

Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.

L1 = L1 means the Sound level exceeded for 1 percent of the measurement duration (i.e., 36 seconds per hour)

Red = Noise Level Exceedance (Project Related)

Blue = Noise Level Exceedance (Not Project Related)

~ = No Data Available

SR520 I5 Mercer Street to SR520 Portage Bay - I5 Interchange Improvements

Major Public Project Construction Noise Variance - #6733975-NV

NOISE MONITORING - WEEKLY REPORT

Monday, June 26, 2023

to

Sunday, July 2, 2023

10 pm to 7 am (weekdays)/ 9am (weekends)

The table below includes data gathered from noise monitoring equipment in the Project area

Tuesday, June 27, 2023													
Site	Site limit (dBA)	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am	
M1 - 624 Yale Ave N	1 Hr Leq	72	71.7	69.6	66.4	66.4	65.8	65.3	67.7	70.8	72.6	N/A	N/A
	1 Hr L1	82	74.9	74.1	70.6	69.3	70.1	68.8	71.1	74.4	76.3	N/A	N/A
M2 - 1547 Boylston Ave E	1 Hr Leq	74	75.5	75.0	70.7	71.0	70.5	71.1	74.4	77.6	78.5	N/A	N/A
	1 Hr L1	84	73.2	71.6	70.2	69.1	69.1	70.3	72.8	75.0	75.9	N/A	N/A
M4 - 3625 Federal Ave E	1 Hr Leq	70	61.2	59.2	56.6	54.3	52.3	53.2	57.2	61.7	62.7	N/A	N/A
	1 Hr L1	80	63.5	61.6	59.5	57.3	55.8	56.4	60.2	64.2	64.6	N/A	N/A
M5 - E Roanoke St & 10th Ave E	1 Hr Leq	71	63.8	61.4	58.7	55.8	54.4	54.9	58.5	64.0	65.2	N/A	N/A
	1 Hr L1	81	66.5	64.1	61.8	58.8	57.8	57.9	61.8	66.2	67.6	N/A	N/A
M6 - 3125 Eastlake Ave E	1 Hr Leq	66	76.0	68.4	63.3	59.8	60.8	60.7	63.1	78.5	80.1	N/A	N/A
	1 Hr L1	76	79.4	71.0	63.9	63.0	63.8	63.9	66.0	81.6	82.3	N/A	N/A
Mobile - 2411 Boylston Ave E	1 Hr Leq	71	77.2	77.1	74.6	73.8	73.6	74.5	77.6	79.7	80.1	N/A	N/A
	1 Hr L1	81	71.6	69.7	68.2	66.7	67.1	68.0	70.4	73.3	74.5	N/A	N/A

Notes recorded by the on-site Independent Noise Monitor

Work:

Walsh, Valley, Transcon and Trenchless were on site between 10:30pm and 3:35 am working on fixing live wire, camera installation, excavating, and boring for loop junction boxes.

Public Comments:

None.

Exceedances:

Sites M1, M2, M6 & Mobile exceedances are not project related. Exceedances are caused by public traffic driving by the noise monitors.

Non-Compliance Events:

None.

Legend

N/A = Time Period not applicable to MPPCNV

Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.

L1 = L1 means the Sound level exceeded for 1 percent of the measurement duration (i.e., 36 seconds per hour)

Red = Noise Level Exceedance (Project Related)

Blue = Noise Level Exceedance (Not Project Related)

~ = No Data Available

**SR520 I5 Mercer Street to SR520 Portage Bay - I5 Interchange Improvements
Major Public Project Construction Noise Variance - #6733975-NV**

NOISE MONITORING - WEEKLY REPORT

Monday, June 26, 2023 to Sunday, July 2, 2023 10 pm to 7 am (weekdays)/ 9am (weekends)

The table below includes data gathered from noise monitoring equipment in the Project area

Wednesday, June 28, 2023													
Site	Site limit (dBA)	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am	
M1 - 624 Yale Ave N	1 Hr Leq	72	71.4	69.8	68.0	66.2	66.2	64.7	67.4	70.8	72.5	N/A	N/A
	1 Hr L1	82	74.8	74.0	72.4	70.0	69.6	67.1	70.7	74.6	75.9	N/A	N/A
M2 - 1547 Boylston Ave E	1 Hr Leq	74	69.9	69.4	69.8	68.3	67.2	67.4	73.4	77.6	78.6	N/A	N/A
	1 Hr L1	84	73.6	72.1	72.5	71.1	70.4	70.0	76.7	79.7	80.1	N/A	N/A
M4 - 3625 Federal Ave E	1 Hr Leq	70	61.5	59.7	57.2	54.8	53.1	53.2	57.1	61.1	63.1	N/A	N/A
	1 Hr L1	80	63.5	61.6	59.7	57.7	55.7	56.3	60.1	63.7	65.0	N/A	N/A
M5 - E Roanoke St & 10th Ave E	1 Hr Leq	71	63.5	62.0	59.0	56.7	54.4	55.3	58.9	63.4	66.3	N/A	N/A
	1 Hr L1	81	66.3	64.6	61.8	59.6	56.8	57.7	62.1	65.8	68.4	N/A	N/A
M6 - 3125 Eastlake Ave E	1 Hr Leq	66	76.6	75.8	74.9	73.2	72.4	73.4	69.3	78.2	79.5	N/A	N/A
	1 Hr L1	76	79.6	79.2	78.4	77.2	76.7	77.5	73.4	81.5	82.0	N/A	N/A
Mobile - 2411 Boylston Ave E	1 Hr Leq	71	70.6	69.2	68.7	66.0	65.4	67.0	69.4	72.5	73.6	N/A	N/A
	1 Hr L1	81	72.1	71.0	69.4	68.1	67.7	69.5	71.6	74.2	75.1	N/A	N/A

Notes recorded by the on-site Independent Noise Monitor

Work:

Walsh, Transcon, Peterson Brothers and Valley were on site between 10:30pm and 3:00 am working on conduit for CMS sign, joint box installation and backfilling, placing the quarry spall in front of wall 21, and placing the concrete barriers.

Public Comments:

None.

Exceedances:

Sites M1, M2, M6 & Mobile exceedances are not project related. Exceedances are caused by public traffic driving by the noise monitors.

Non-Compliance Events:

None.

Legend

N/A = Time Period not applicable to MPPCNV

Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.

L1 = L1 means the Sound level exceeded for 1 percent of the measurement duration (i.e., 36 seconds per hour)

Red = Noise Level Exceedance (Project Related)

Blue = Noise Level Exceedance (Not Project Related)

~ = No Data Available

**SR520 I5 Mercer Street to SR520 Portage Bay - I5 Interchange Improvements
Major Public Project Construction Noise Variance - #6733975-NV**

NOISE MONITORING - WEEKLY REPORT

Monday, June 26, 2023 to Sunday, July 2, 2023 10 pm to 7 am (weekdays)/ 9am (weekends)

The table below includes data gathered from noise monitoring equipment in the Project area

Thursday, June 29, 2023													
Site	Site limit (dBA)	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am	
M1 - 624 Yale Ave N	1 Hr Leq	72	71.2	70.2	67.1	65.6	66.8	65.7	67.9	70.9	73.4	N/A	N/A
	1 Hr L1	82	74.4	74.2	71.1	69.3	70.6	68.9	71.3	74.5	75.6	N/A	N/A
M2 - 1547 Boylston Ave E	1 Hr Leq	74	69.9	69.4	69.8	68.3	67.2	67.4	73.4	77.6	78.6	N/A	N/A
	1 Hr L1	84	73.6	72.1	72.5	71.1	70.4	70.0	76.7	79.7	80.1	N/A	N/A
M4 - 3625 Federal Ave E	1 Hr Leq	70	60.9	60.5	56.7	54.1	53.4	52.8	57.6	61.0	62.8	N/A	N/A
	1 Hr L1	80	62.7	61.4	59.5	57.4	55.8	56.7	60.6	63.5	64.5	N/A	N/A
M5 - E Roanoke St & 10th Ave E	1 Hr Leq	71	63.8	65.2	59.6	56.9	55.1	55.3	59.1	62.9	65.3	N/A	N/A
	1 Hr L1	81	66.4	64.3	62.4	59.9	57.8	58.5	62.2	65.4	67.7	N/A	N/A
M6 - 3125 Eastlake Ave E	1 Hr Leq	66	76.6	77.1	75.6	74.3	73.5	74.2	69.4	78.5	79.6	N/A	N/A
	1 Hr L1	76	79.7	79.3	78.9	78.0	77.3	78.5	73.1	81.7	82.3	N/A	N/A
Mobile - 2411 Boylston Ave E	1 Hr Leq	71	69.7	78.9	67.7	66.4	65.1	67.1	67.8	71.2	72.3	N/A	N/A
	1 Hr L1	81	71.7	71.1	69.4	68.5	67.7	69.1	69.9	72.7	74.0	N/A	N/A

Notes recorded by the on-site Independent Noise Monitor

Work:

Walsh, Trenchless and Valley were on site between 10:30pm and 3:00 am working on conduit for CMC sign, drilling for CMC sign, drilling for MEC panels, and running the power wire.

Public Comments:

None.

Exceedances:

Sites M1, M2, M6 & Mobile exceedances are not project related. Exceedances are caused by public traffic driving by the noise monitors.

Non-Compliance Events:

None.

Legend

N/A = Time Period not applicable to MPPCNV

Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.

L1 = L1 means the Sound level exceeded for 1 percent of the measurement duration (i.e., 36 seconds per hour)

Red = Noise Level Exceedance (Project Related)

Blue = Noise Level Exceedance (Not Project Related)

~ = No Data Available

**SR520 I5 Mercer Street to SR520 Portage Bay - I5 Interchange Improvements
Major Public Project Construction Noise Variance - #6733975-NV**

NOISE MONITORING - WEEKLY REPORT

Monday, June 26, 2023 to Sunday, July 2, 2023 10 pm to 7 am (weekdays)/ 9am (weekends)

The table below includes data gathered from noise monitoring equipment in the Project area

Friday, June 30, 2023													
Site	Site limit (dBA)	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am	
M1 - 624 Yale Ave N	1 Hr Leq	72	71.7	71.5	70.1	70.3	68.3	70.3	65.8	68.2	69.9	70.2	71.3
	1 Hr L1	82	75.0	75.0	74.0	73.6	72.1	70.4	69.3	72.3	73.9	74.1	74.9
M2 - 1547 Boylston Ave E	1 Hr Leq	74	74.9	71.8	74.6	73.8	72.9	70.8	72.0	73.4	75.5	76.7	76.8
	1 Hr L1	84	76.7	75.8	76.7	76.2	75.5	74.0	75.0	76.3	77.9	78.4	78.3
M4 - 3625 Federal Ave E	1 Hr Leq	70	59.9	57.7	56.9	55.6	54.6	52.6	52.7	55.7	57.5	57.7	59.1
	1 Hr L1	80	60.9	59.8	59.1	57.8	57.3	56.0	55.9	58.4	59.8	60.5	61.8
M5 - E Roanoke St & 10th Ave E	1 Hr Leq	71	67.0	62.8	60.1	58.6	57.2	55.7	55.7	58.6	61.0	63.0	64.6
	1 Hr L1	81	67.1	65.6	63.0	61.5	59.5	58.6	57.9	61.3	64.6	66.9	68.3
M6 - 3125 Eastlake Ave E	1 Hr Leq	66	76.5	70.7	62.6	63.9	60.8	60.3	60.4	62.3	64.2	65.2	77.1
	1 Hr L1	76	79.6	75.4	64.6	64.0	63.5	63.2	63.3	65.0	66.2	66.8	80.3
Mobile - 2411 Boylston Ave E	1 Hr Leq	71	70.7	69.1	68.6	67.2	66.8	65.4	66.1	67.8	69.6	70.0	70.8
	1 Hr L1	81	72.3	71.3	70.7	69.3	68.7	67.7	68.1	69.9	71.6	72.1	73.0

Notes recorded by the on-site Independent Noise Monitor

Work:
No work performed.

Public Comments:
None.

Exceedances:
Sites M1, M2, M6 & Mobile exceedances are not project related. Exceedances are caused by public traffic driving by the noise monitors.

Non-Compliance Events:
None.

Legend

N/A = Time Period not applicable to MPPCNV
 Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.
 L1 = L1 means the Sound level exceeded for 1 percent of the measurement duration (i.e., 36 seconds per hour)
 Red = Noise Level Exceedance (Project Related)
 Blue = Noise Level Exceedance (Not Project Related)
 ~ = No Data Available

**SR520 I5 Mercer Street to SR520 Portage Bay - I5 Interchange Improvements
Major Public Project Construction Noise Variance - #6733975-NV**

NOISE MONITORING - WEEKLY REPORT

Monday, June 26, 2023 to Sunday, July 2, 2023 10 pm to 7 am (weekdays)/ 9am (weekends)

The table below includes data gathered from noise monitoring equipment in the Project area

Saturday, July 1, 2023													
Site	Site limit (dBA)	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am	
M1 - 624 Yale Ave N	1 Hr Leq	72	71.6	71.1	70.0	69.5	68.2	65.2	65.3	66.6	69.1	68.9	70.5
	1 Hr L1	82	75.0	74.9	74.3	73.7	73.0	68.6	68.8	70.5	73.4	73.3	74.3
M2 - 1547 Boylston Ave E	1 Hr Leq	74	72.6	74.6	74.6	73.5	72.8	71.3	72.2	72.5	74.3	75.3	76.2
	1 Hr L1	84	75.7	76.6	76.5	75.9	75.5	74.5	74.4	75.4	76.8	77.6	78.2
M4 - 3625 Federal Ave E	1 Hr Leq	70	59.0	58.2	56.6	54.2	52.0	52.1	53.1	54.8	57.0	58.6	59.1
	1 Hr L1	80	60.9	60.6	59.5	57.3	55.1	54.5	55.6	57.4	59.8	61.0	61.8
M5 - E Roanoke St & 10th Ave E	1 Hr Leq	71	63.3	62.2	61.0	58.8	57.4	55.5	55.0	57.9	59.8	61.3	63.3
	1 Hr L1	81	67.0	65.4	63.9	61.3	60.3	57.1	56.5	60.4	62.7	64.8	67.0
M6 - 3125 Eastlake Ave E	1 Hr Leq	66	77.1	70.2	63.2	63.4	60.6	59.3	59.5	61.3	62.8	63.9	75.2
	1 Hr L1	76	80.1	75.0	64.9	64.0	63.3	62.1	62.4	63.9	65.1	65.8	78.8
Mobile - 2411 Boylston Ave E	1 Hr Leq	71	71.0	69.5	68.7	70.1	69.0	65.5	65.7	67.6	68.9	70.6	72.2
	1 Hr L1	81	72.5	71.7	70.6	69.3	68.6	67.5	67.8	69.6	70.6	73.1	74.7

Notes recorded by the on-site Independent Noise Monitor

Work:
No work performed.

Public Comments:
None

Exceedances:
Sites M1, M2, M6 & Mobile exceedances are not project related. Exceedances are caused by public traffic driving by the noise monitors.

Non-Compliance Events:
None.

Legend

N/A = Time Period not applicable to MPPCNV
 Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.
 L1 = L1 means the Sound level exceeded for 1 percent of the measurement duration (i.e., 36 seconds per hour)
 Red = Noise Level Exceedance (Project Related)
 Blue = Noise Level Exceedance (Not Project Related)
 ~ = No Data Available

**SR520 I5 Mercer Street to SR520 Portage Bay - I5 Interchange Improvements
Major Public Project Construction Noise Variance - #6733975-NV**

NOISE MONITORING - WEEKLY REPORT

Monday, June 26, 2023 to Sunday, July 2, 2023 10 pm to 7 am (weekdays)/ 9am (weekends)

The table below includes data gathered from noise monitoring equipment in the Project area

Sunday, July 2, 2023													
Site	Site limit (dBA)	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am	
M1 - 624 Yale Ave N	1 Hr Leq	72	70.5	69.0	68.2	65.8	64.6	63.6	67.1	69.7	72.0	N/A	N/A
	1 Hr L1	82	74.3	73.5	72.7	69.6	67.3	65.4	70.0	73.6	75.3	N/A	N/A
M2 - 1547 Boylston Ave E	1 Hr Leq	74	74.9	74.6	73.3	71.1	70.9	70.7	72.7	76.3	77.9	N/A	N/A
	1 Hr L1	84	76.6	76.7	75.9	74.4	74.3	74.2	75.9	78.9	79.7	N/A	N/A
M4 - 3625 Federal Ave E	1 Hr Leq	70	60.2	59.3	54.8	52.0	51.0	51.3	55.0	61.0	63.0	N/A	N/A
	1 Hr L1	80	61.9	60.5	57.3	54.5	53.7	53.8	57.5	63.1	64.7	N/A	N/A
M5 - E Roanoke St & 10th Ave E	1 Hr Leq	71	62.0	71.6	56.9	55.3	53.8	53.9	56.4	62.0	64.5	N/A	N/A
	1 Hr L1	81	64.8	63.8	59.7	57.9	55.6	55.6	58.6	64.8	66.6	N/A	N/A
M6 - 3125 Eastlake Ave E	1 Hr Leq	66	73.8	67.4	60.9	59.6	59.1	59.2	61.8	76.6	78.4	N/A	N/A
	1 Hr L1	76	77.5	70.4	63.5	62.5	62.5	62.6	64.7	80.2	81.2	N/A	N/A
Mobile - 2411 Boylston Ave E	1 Hr Leq	71	71.4	69.1	67.8	64.6	65.0	65.5	68.3	71.2	72.7	N/A	N/A
	1 Hr L1	81	72.7	71.1	70.5	66.8	67.5	68.3	70.6	73.0	74.2	N/A	N/A

Notes recorded by the on-site Independent Noise Monitor

Work:
No work performed.

Public Comments:
None.

Exceedances:
Sites M1, M2, M6 & Mobile exceedances are not project related. Exceedances are caused by public traffic driving by the noise monitors.

Non-Compliance Events:
None.

Legend

N/A = Time Period not applicable to MPPCNV
 Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.
 L1 = L1 means the Sound level exceeded for 1 percent of the measurement duration (i.e., 36 seconds per hour)
 Red = Noise Level Exceedance (Project Related)
 Blue = Noise Level Exceedance (Not Project Related)
 ~ = No Data Available

SR520 I5 Mercer Street to SR520 Portage Bay - I5 Interchange Improvements

Major Public Project Construction Noise Variance - #6733975-NV

NOISE MONITORING - WEEKLY REPORT

Monday, June 26, 2023 to Sunday, July 2, 2023

10 p.m. to 7 a.m. (weekdays)/ 9a.m. (weekends)

Public Comment Log			
Date / Time	To/From	Issue	Resolution