

SR 520 Montlake Project

Noise Monitoring Weekly Report Summary for **Monday, April 18, 2022** to **Sunday, April 24, 2022**

PUBLISHED April 27th, 2022

Monitoring times: Weekdays, 10 p.m. to 7 a.m.; weekends, 10 p.m. to 9 a.m.

How to use this report: This document summarizes the weekly nighttime noise data for the SR 520 Montlake Project. In it, you'll find:

- Page 1 - Summary of noise levels recorded above the limits allowed under the Major Public Project Construction Noise Variance, for this week and throughout the project. This includes non -project-related noise exceedances
- Page 2 - Map of the project limits and locations of the seven stationary monitor locations
- Pages 3 – 9 - Night -by-night noise recordings for each of the project noise monitors, along with a description of the work that night, comments received from the public regarding Project noise, and explanations for any noise limit exceedances and actions taken in response
- Page 10 - Log of public comments regarding nighttime noise issues and resolutions for the week

WSDOT is sharing this information as per the terms of the Major Public Project Construction Noise Variance (Permit #3030792).

MPPCNV start date: **Friday, August 16, 2019**


MPPCNV days to date: **983**

WEEKLY TOTALS	
Nights worked this week (under the MPPCNV)	4
Project related non-compliance this week	0
Nighttime noise issue comments to the project	0
Non-project-related noise exceedances this week	23

PROJECT TOTALS TO DATE	
Total Nights Worked (under the MPPCNV)	487
Total Project related non-compliance	113
Total noise issue comments to the project	116
Total non-project related exceedances	3647

Noise Monitoring Locations: the map below shows the work limits of the SR 520 Montlake Project and the locations of the seven stationary noise monitoring sites

EXHIBIT 5. CONSTRUCTION AREA AND NOISE MEASUREMENT LOCATIONS



SR 520 Montlake Project
Major Public Project Construction Noise Variance
NOISE MONITORING - WEEKLY REPORT
Monday, April 18, 2022 to Sunday, April 24, 2022 10 pm to 7 am (weekdays) / 9am (weekends)

The table below includes data gathered from noise monitoring equipment located at seven stationary and three portable locations throughout the Montlake Project area

Monday, April 18, 2022												
Site	Site limit*	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am
Site 1 -2449 E. Lk WA Blvd	67	48.9	48.0	45.2	45.7	43.9	45.2	48.6	50.9	54.2	N/A	N/A
Site 2 - 2015 E. Roanoke St	78	59.2	56.6	55.4	54.2	51.2	53.7	56.5	60.4	62.8	N/A	N/A
Site 3A - Canterbury Shores	62	50.8	48.5	46.7	47.7	47.5	46.2	49.3	50.6	53.8	N/A	N/A
Site 4 - 2800 Montlake Blvd E	66	65.6	63.2	60.8	58.2	57.3	61.1	63.3	67.5	70.0	N/A	N/A
Site 5 - 2565 22nd Av E.	65	58.1	55.5	55.4	52.8	50.1	52.1	55.4	58.7	61.4	N/A	N/A
Site 6 - 2160 E. Hamlin St	63	57.6	55.3	53.3	52.4	50.6	50.9	54.0	57.3	58.4	N/A	N/A
Site 7 - 2209 E. Lake Wa Blvd	66	51.6	50.7	47.3	50.2	43.0	44.6	48.5	53.5	54.4	N/A	N/A
Site 8 - Portable Between Sites 4 and 6	63	58.4	56.0	53.4	53.0	50.8	52.3	54.6	58.5	61.3	N/A	N/A
Site 9 - Portable Between Sites 1 and 7	66	62.3	59.2	56.6	62.0	53.2	56.6	58.8	63.2	64.9	N/A	N/A
Site 10 - Portable Between Sites 1 and 7	66	66.3	61.6	59	57.3	55.4	56.2	59.2	64.5	66.5	N/A	N/A

*Hourly-Average Leq (dBA)

Notes recorded by the on-site Independent Noise Monitor

Work:
Design-Builder worked between 10:00pm and 5:00am moving equipment from pier 2 and laying rebar, & pulling wire under the lid

Public Comments:
No public comments received related to nighttime noise.

Exceedances:
Sites 4, & 10 exceedances are due to public traffic. **(Non work related).**

Non-Compliance:
None.

Legend
Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.
N/A = Time Period not applicable to MPPCNV
Red = Noise Level Exceedance, project related
Blue = Noise level exceedance, not project related
~ = No Data Available
= No contract work . Portable monitors are not being used (not needed).

SR 520 Montlake Project
Major Public Project Construction Noise Variance
NOISE MONITORING - WEEKLY REPORT
Monday, April 18, 2022 to Sunday, April 24, 2022 10 pm to 7 am (weekdays) / 9am (weekends)

The table below includes data gathered from noise monitoring equipment located at seven stationary and three portable locations throughout the Montlake Project area

Tuesday, April 19, 2022												
Site	Site limit*	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am
Site 1 -2449 E. Lk WA Blvd	67	49.3	49.5	47.0	47.1	44.8	48.2	50.3	55.1	58.2	N/A	N/A
Site 2 - 2015 E. Roanoke St	78	61.1	57.5	59.5	54.0	52.6	53.9	56.5	59.9	63.4	N/A	N/A
Site 3A - Canterbury Shores	62	51.7	47.0	44.9	44.8	41.7	41.6	46.3	51.3	55.8	N/A	N/A
Site 4 - 2800 Montlake Blvd E	66	66.6	62.1	67.8	59.0	57.9	60.1	62.3	66.3	69.0	N/A	N/A
Site 5 - 2565 22nd Av E.	65	59.5	56.1	57.9	52.7	50.9	51.9	54.0	57.8	61.7	N/A	N/A
Site 6 - 2160 E. Hamlin St	63	51.6	54.8	51.4	50.9	47.2	50.0	53.3	60.2	57.6	N/A	N/A
Site 7 - 2209 E. Lake Wa Blvd	66	48.5	48.6	50.5	45.1	42.7	46.1	49.0	53.7	55.4	N/A	N/A
Site 8 - Portable Between Sites 4 and 6	63	54.1	55.7	53.7	52.9	48.6	52.0	54.4	60.0	59.4	N/A	N/A
Site 9 - Portable Between Sites 1 and 7	66	59.8	57.3	64.8	54.8	53.3	56.0	56.5	61.1	63.8	N/A	N/A
Site 10 - Portable Between Sites 1 and 7	66	63.0	60.6	58.4	56.3	54.1	57.6	60.0	65.4	68.0	N/A	N/A

*Hourly-Average Leq (dBA)

Notes recorded by the on-site Independent Noise Monitor

Work:

Elcon worked between 10:00pm and 3:30am pulling wire under the lid

Public Comments:

No public comments received related to nighttime noise.

Exceedances:

Sites 4, & 10 exceedances are due to public traffic. **(Non work related).**

Non-Compliance:

None.

Legend

Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.

N/A = Time Period not applicable to MPPCNV

Red = Noise Level Exceedance, project related

Blue = Noise level exceedance, not project related

~ = No Data Available

= No contract work . Portable monitors are not being used (not needed).

SR 520 Montlake Project
Major Public Project Construction Noise Variance
NOISE MONITORING - WEEKLY REPORT
Monday, April 18, 2022 to Sunday, April 24, 2022 10 pm to 7 am (weekdays) / 9am (weekends)

The table below includes data gathered from noise monitoring equipment located at seven stationary and three portable locations throughout the Montlake Project area

Wednesday, April 20, 2022												
Site	Site limit*	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am
Site 1 - 2449 E. Lk WA Blvd	67	52.6	51.5	49.3	47.7	44	45.9	47.1	51.7	55.5	N/A	N/A
Site 2 - 2015 E. Roanoke St	78	60.8	59.9	57.3	55.3	53.7	55	57	60.3	63.3	N/A	N/A
Site 3A - Canterbury Shores	62	52.9	50.5	47.8	46	45.1	46.1	47.9	49.4	54.2	N/A	N/A
Site 4 - 2800 Montlake Blvd E	66	65.6	63.6	60.3	58.1	57.3	59.4	64.3	68.2	69.9	N/A	N/A
Site 5 - 2565 22nd Av E.	65	59.4	58.3	55.6	53.8	52.2	53.5	56	58.7	61.8	N/A	N/A
Site 6 - 2160 E. Hamlin St	63	54.5	54.2	53	50.3	48.2	48.8	51.4	58.5	58	N/A	N/A
Site 7 - 2209 E. Lake Wa Blvd	66	51.3	49.9	47.4	46.3	42.7	45.6	52.3	53.6	55.6	N/A	N/A
Site 8 - Portable Between Sites 4 and 6	63	56.9	56.7	54.7	52.4	49.8	50.4	51.5	57.6	61.1	N/A	N/A
Site 9 - Portable Between Sites 1 and 7	66	61.6	60.5	56.9	58	54.1	56.7	58.9	63.9	66	N/A	N/A
Site 10 - Portable Between Sites 1 and 7	66	65.5	63	59.5	57.4	53.5	57.5	58.2	64.9	67.7	N/A	N/A

*Hourly-Average Leq (dBA)

Notes recorded by the on-site Independent Noise Monitor

Work:

Elcon worked between 10:00pm and 3:30am pulling wire under the lid

Public Comments:

No public comments received related to nighttime noise.

Exceedances:

Sites 4, 9, & 10 exceedances are due to public traffic. **(Non work related).**

Non-Compliance:

None

Legend

Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.

N/A = Time Period not applicable to MPPCNV

Red = Noise Level Exceedance, project related

Blue = Noise level exceedance, not project related

~ = No Data Available

= No contract work . Portable monitors are not being used (not needed).

SR 520 Montlake Project
Major Public Project Construction Noise Variance
NOISE MONITORING - WEEKLY REPORT
Monday, April 18, 2022 to Sunday, April 24, 2022 10 pm to 7 am (weekdays) / 9am (weekends)

The table below includes data gathered from noise monitoring equipment located at seven stationary and three portable locations throughout the Montlake Project area

Thursday, April 21, 2022												
Site	Site limit*	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am
Site 1 -2449 E. Lk WA Blvd	67	53.0	51.4	47.6	46.1	42.6	45.4	47.3	50.9	54.0	N/A	N/A
Site 2 - 2015 E. Roanoke St	78	64.5	59.2	56.9	54.6	53.1	54.0	55.7	58.6	62.0	N/A	N/A
Site 3A - Canterbury Shores	62	51.2	49.8	47.4	45.6	43.8	44.1	46.8	50.3	53.1	N/A	N/A
Site 4 - 2800 Montlake Blvd E	66	71.1	63.7	61.1	58.5	57.6	59.4	62.7	66.0	69.1	N/A	N/A
Site 5 - 2565 22nd Av E.	65	64.2	57.9	55.3	53.2	51.5	52.9	54.5	56.9	60.6	N/A	N/A
Site 6 - 2160 E. Hamlin St	63	55.2	56.8	52.3	51.3	49.0	49.8	53.3	57.4	55.8	N/A	N/A
Site 7 - 2209 E. Lake Wa Blvd	66	54.6	50.6	47.0	45.4	43.3	46.0	47.9	51.9	53.5	N/A	N/A
Site 8 - Portable Between Sites 4 and 6	63	58.1	57.9	53.9	52.8	50.5	51.2	53.8	57.5	60.0	N/A	N/A
Site 9 - Portable Between Sites 1 and 7	66	68.7	60.0	56.5	54.4	53.4	57.4	57.3	59.9	62.9	N/A	N/A
Site 10 - Portable Between Sites 1 and 7	66	65.0	63.0	58.2	55.8	53.1	56.5	59.1	61.4	66.1	N/A	N/A

*Hourly-Average Leq (dBA)

Notes recorded by the on-site Independent Noise Monitor

Work:

Elcon worked between 10:00pm and 3:30am pulling wire under the lid

Public Comments:

No public comments received related to nighttime noise.

Exceedances:

Site(s) 4, 9, & 10 exceedances are due to public traffic driving by the noise monitors (**not work related**).

Non-Compliance:

None

Legend

Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.

N/A = Time Period not applicable to MPPCNV

Red = Noise Level Exceedance, project related

Blue = Noise level exceedance, not project related

~ = No Data Available

= No contract work . Portable monitors are not being used (not needed).

SR 520 Montlake Project
Major Public Project Construction Noise Variance
NOISE MONITORING - WEEKLY REPORT
Monday, April 18, 2022 to Sunday, April 24, 2022 10 pm to 7 am (weekdays) / 9am (weekends)

The table below includes data gathered from noise monitoring equipment located at seven stationary and three portable locations throughout the Montlake Project area

Friday, April 22, 2022												
Site	Site limit*	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am
Site 1 -2449 E. Lk WA Blvd	67	54.0	52.8	49.9	48.0	46.4	45.4	42.2	46.2	48.4	49.9	51.5
Site 2 - 2015 E. Roanoke St	78	60.8	59.8	57.9	55.9	54.5	52.5	51.7	55.9	58.6	60.0	61.4
Site 3A - Canterbury Shores	62	53.3	51.7	49.6	48.2	46.1	46.6	44.1	47.6	49.3	50.8	52.3
Site 4 - 2800 Montlake Blvd E	66	65.4	65.3	62.4	60.7	59.7	56.9	57.5	62.0	66.1	66.1	67.7
Site 5 - 2565 22nd Av E.	65	62.7	59.4	58.3	56.5	54.6	53.0	50.6	50.4	54.8	57.1	58.5
Site 6 - 2160 E. Hamlin St	63	55.4	53.0	52.7	52.3	52.0	51.8	50.5	55.5	50.9	52.9	55.7
Site 7 - 2209 E. Lake Wa Blvd	66	57.0	54.7	53.0	51.5	50.1	49.9	48.0	56.6	53.8	54.7	55.7
Site 8 - Portable Between Sites 4 and 6	63	61.2	57.0	54.4	54.5	53.0	52.0	48.6	53.8	56.3	58.1	57.8
Site 9 - Portable Between Sites 1 and 7	66	60.4	58.9	58.5	55.7	54.2	53.1	51.2	57.3	59.0	59.9	61.6
Site 10 - Portable Between Sites 1 and 7	66	65.3	63.4	61.0	57.4	56.1	56.0	52.0	58.8	61.5	64.5	66.5

*Hourly-Average Leq (dBA)

Notes recorded by the on-site Independent Noise Monitor

Work:

No nighttime construction work performed.

Public Comments:

No public comments received related to nighttime noise.

Exceedances:

Site(s) 4, & 10 exceedances are due to public traffic driving by the noise monitors **(not work related)**.

Non-Compliance:

None

Legend

Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.

N/A = Time Period not applicable to MPPCNV

Red = Noise Level Exceedance, project related

Blue = Noise level exceedance, not project related

~ = No Data Available

= No contract work . Portable monitors are not being used (not needed).

SR 520 Montlake Project
Major Public Project Construction Noise Variance
NOISE MONITORING - WEEKLY REPORT
Monday, April 18, 2022 to Sunday, April 24, 2022 10 pm to 7 am (weekdays) / 9am (weekends)

The table below includes data gathered from noise monitoring equipment located at seven stationary and three portable locations throughout the Montlake Project area

Saturday, April 23, 2022												
Site	Site limit*	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am
Site 1 -2449 E. Lk WA Blvd	67	55.2	53.1	52	51.1	48.2	46.9	44.3	48.3	51.1	50.5	51.6
Site 2 - 2015 E. Roanoke St	78	62.3	61.6	59.6	58	56.3	55.5	53.1	56	58.8	60.2	59.6
Site 3A - Canterbury Shores	62	53.5	52.9	51.0	47.9	46.9	45.1	41.3	46.6	47.7	48.6	51.2
Site 4 - 2800 Montlake Blvd E	66	65.5	64.5	62.8	61.4	59.9	59.1	58.7	62.2	64.9	65.4	65.1
Site 5 - 2565 22nd Av E.	65	60.9	60.2	58.2	56.5	54.6	53.8	51.5	55.3	58.5	59.0	58.1
Site 6 - 2160 E. Hamlin St	63	59.7	57.6	58.4	56.1	55.1	54.6	51.5	58.6	57.3	56.3	54.1
Site 7 - 2209 E. Lake Wa Blvd	66	57.9	55.8	54.9	54.6	52.1	50.1	48.6	52.0	54.0	55.2	55.0
Site 8 - Portable Between Sites 4 and 6	63	60.4	57.9	58.3	56.7	55.3	53.8	50.4	56.5	58.9	57.0	56.8
Site 9 - Portable Between Sites 1 and 7	66	61.6	60.1	58.5	57.7	55.5	54.3	53.6	56.3	59.4	61.4	60.0
Site 10 - Portable Between Sites 1 and 7	66	65.8	63.3	60.6	59.5	56.7	56.3	55.0	57.8	60.9	62.6	65.0

*Hourly-Average Leq (dBA)

Notes recorded by the on-site Independent Noise Monitor

Work:

No nighttime construction work performed.

Public Comments:

No public comments received related to nighttime noise.

Exceedances:

None

Non-Compliance:

None

Legend

Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.

N/A = Time Period not applicable to MPPCNV

Red = Noise Level Exceedance, project related

Blue = Noise level exceedance, not project related

~ = No Data Available

= No contract work . Portable monitors are not being used (not needed).

SR 520 Montlake Project
Major Public Project Construction Noise Variance
NOISE MONITORING - WEEKLY REPORT
Monday, April 18, 2022 to Sunday, April 24, 2022 10 pm to 7 am (weekdays) / 9am (weekends)

The table below includes data gathered from noise monitoring equipment located at seven stationary and three portable locations throughout the Montlake Project area

Sunday, April 24, 2022												
Site	Site limit*	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am
Site 1 -2449 E. Lk WA Blvd	67	47.1	45.4	42.8	42.0	38.7	41.4	47.5	50.1	53.2	N/A	N/A
Site 2 - 2015 E. Roanoke St	78	59.2	57.0	55.5	52.8	53.4	51.3	59.3	60.5	62.8	N/A	N/A
Site 3A - Canterbury Shores	62	49.6	48.1	47.0	45.3	42.8	39.5	49.1	51.1	52.7	N/A	N/A
Site 4 - 2800 Montlake Blvd E	66	64.7	63.1	57.2	60.7	58.5	58.9	57.5	56.1	59.8	N/A	N/A
Site 5 - 2565 22nd Av E.	65	57.9	55.9	54.0	53.5	52.8	50.0	59.8	60.2	61.0	N/A	N/A
Site 6 - 2160 E. Hamlin St	63	52.6	51.3	49.5	47.3	47.5	46.1	52.1	56.9	57	N/A	N/A
Site 7 - 2209 E. Lake Wa Blvd	66	52.4	50.8	48.7	47.4	46.4	45.2	52.7	56.1	58.1	N/A	N/A
Site 8 - Portable Between Sites 4 and 6	63	55.0	53.3	52.6	48.1	49.4	47.8	52.5	56.9	59.9	N/A	N/A
Site 9 - Portable Between Sites 1 and 7	66	59.3	58.6	56.4	54.5	54.0	54.4	60.1	64.8	65.5	N/A	N/A
Site 10 - Portable Between Sites 1 and 7	66	61.4	57.8	55.6	52.5	50.3	48.4	58.6	64.7	67.0	N/A	N/A

*Hourly-Average Leq (dBA)

Notes recorded by the on-site Independent Noise Monitor

Work:

No nighttime construction work performed.

Public Comments:

No public comments received related to nighttime noise.

Exceedances:

Site(s) 10 exceedance is due to public traffic driving by the noise monitors (**not work related**).

Non-Compliance:

None

Legend

Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.

N/A = Time Period not applicable to MPPCNV

Red = Noise Level Exceedance, project related

Blue = Noise level exceedance, not project related

~ = No Data Available

= No contract work . Portable monitors are not being used (not needed).

SR 520 Montlake Project
Major Public Project Construction Noise Variance
NOISE MONITORING - WEEKLY REPORT

Monday, April 18, 2022 to Sunday, April 24, 2022

10 p.m. to 7 a.m. (weekdays)/9a.m. (weekends)

Public Comment Log			
Date / Time	To/From	Issue	Resolution