

SR 520 Montlake Project

Noise Monitoring Weekly Report Summary for **Monday, January 25, 2021** to **Sunday, January 31, 2021**

PUBLISHED FEBRUARY 3, 2021

Monitoring times: Weekdays, 10 p.m. to 7 a.m.; weekends, 10 p.m. to 9 a.m.

How to use this report: This document summarizes the weekly nighttime noise data for the SR 520 Montlake Project. In it, you'll find:

- Page 1 - Summary of noise levels recorded above the limits allowed under the Major Public Project Construction Noise Variance, for this week and throughout the project. This includes non-project-related noise exceedances
- Page 2 - Map of the project limits and locations of the seven stationary monitor locations
- Pages 3 – 9 - Night-by-night noise recordings for each of the project noise monitors, along with a description of the work that night, comments received from the public regarding Project noise, and explanations for any noise limit exceedances and actions taken in response
- Page 10 - Log of public comments regarding nighttime noise issues and resolutions for the week

WSDOT is sharing this information as per the terms of the Major Public Project Construction Noise Variance (Permit #3030792).

MPPCNV start date: Friday, August 16, 2019

MPPCNV days to date: 535

WEEKLY TOTALS	
Nights worked this week (under the MPPCNV)	7
Project related non-compliance this week	3
Nighttime noise issue comments to the project	2
Non-project-related noise exceedances this week	33

PROJECT TOTALS TO DATE	
Total Nights Worked (under the MPPCNV)	182
Total Project related non-compliance	52
Total noise issue comments to the project	52
Total non-project related exceedances	2130

Noise Monitoring Locations: the map below shows the work limits of the SR 520 Montlake Project and the locations of the seven stationary noise monitoring sites

EXHIBIT 5. CONSTRUCTION AREA AND NOISE MEASUREMENT LOCATIONS



SR 520 Montlake Project
Major Public Project Construction Noise Variance
NOISE MONITORING - WEEKLY REPORT
Monday, January 25, 2021 to Sunday, January 31, 2021 10 pm to 7 am (weekdays) / 9am (weekends)

The table below includes data gathered from noise monitoring equipment located at seven stationary and three portable locations throughout the Montlake Project area

Monday, January 25, 2021												
Site	Site limit*	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am
Site 1 - 2449 E. Lk WA Blvd	67	56.5	55.3	55.1	53.3	51.8	51.4	52.9	56.4	59.4	N/A	N/A
Site 2 - 2015 E. Roanoke St	78	58.4	57.3	54.2	53.4	54.1	54.7	57.0	60.2	63.5	N/A	N/A
Site 3A - 3810 E. McGilvra St	62	44.9	44.3	43.9	42.1	41.9	42.6	42.5	48.4	51.3	N/A	N/A
Site 4 - 2800 Montlake Blvd E	66	64.5	62.6	61.2	59.0	60.6	60.6	64.2	68.7	69.7	N/A	N/A
Site 5 - 2565 22nd Av E.	65	56.7	55.0	52.0	51.1	52.0	52.7	54.6	58.1	61.4	N/A	N/A
Site 6 - 2160 E. Hamlin St	63	55.8	53.3	54.1	51.5	51.4	52.7	53.9	55.2	56.4	N/A	N/A
Site 7 - 2209 E. Lake Wa Blvd	66	53.5	51.8	51.3	50.6	48.6	48.8	51.4	55.0	59.1	N/A	N/A
Site 8 - Portable Between Sites 4 and 6	63	55.0	52.6	50.8	49.2	50.7	52.3	52.3	55.8	57.6	N/A	N/A
Site 9 - Portable Between Sites 1 and 7	66	64.0	61.0	63.2	60.2	54.4	54.0	58.6	62.5	66.0	N/A	N/A
Site 10 - Portable Between Sites 1 and 7	66	61.3	58.5	58.0	59.2	56.8	55.0	58.3	63.3	66.5	N/A	N/A
*Hourly-Average Leq (dBA)												

Notes recorded by the on-site Independent Noise Monitor

Work:
Design-Builder worked between 10:00pm and 7:00am to install bull rail, weld steel plates, install conduit and set up for day work.

Public Comments:
No public comments received related to nighttime noise.

Exceedances:
Site(s) 4, 9 and 10 are not project related. Exceedances are caused by public traffic driving by the noise monitors.

Non-Compliance:
None.

Legend
Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.
N/A = Time Period not applicable to MPPCNV
Red = Noise Level Exceedance, project related
Blue = Noise level exceedance, not project related
~ = No Data Available
= No contract work . Portable monitors are not being used (not needed).

SR 520 Montlake Project
Major Public Project Construction Noise Variance
NOISE MONITORING - WEEKLY REPORT

Monday, January 25, 2021 to Sunday, January 31, 2021 10 pm to 7 am (weekdays) / 9am (weekends)

The table below includes data gathered from noise monitoring equipment located at seven stationary and three portable locations throughout the Montlake Project area

Tuesday, January 26, 2021												
Site	Site limit*	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am
Site 1 - 2449 E. Lk WA Blvd	67	54.9	56.1	52.7	51.1	51.0	51.0	51.8	56.0	60.1	N/A	N/A
Site 2 - 2015 E. Roanoke St	78	56.8	56.7	55.1	54.2	55.1	52.9	55.9	61.4	62.9	N/A	N/A
Site 3A - 3810 E. McGilvra St	62	51.1	53.1	50.5	44.1	40.6	40.0	44.9	49.1	50.8	N/A	N/A
Site 4 - 2800 Montlake Blvd E	66	63.8	62.5	60.4	59.3	58.2	57.2	63.7	69.1	71.0	N/A	N/A
Site 5 - 2565 22nd Av E.	65	54.8	54.7	53.4	52.2	53.2	50.7	53.4	58.8	61.0	N/A	N/A
Site 6 - 2160 E. Hamlin St	63	54.4	52.9	50.6	47.1	49.0	48.7	51.0	54.4	57.2	N/A	N/A
Site 7 - 2209 E. Lake Wa Blvd	66	54.3	54.7	49.8	48.5	49.9	47.2	49.8	54.5	59.6	N/A	N/A
Site 8 - Portable Between Sites 4 and 6	63	52.3	51.8	49.5	48.8	49.6	49.0	50.1	55.6	58.8	N/A	N/A
Site 9 - Portable Between Sites 1 and 7	66	61.3	62.5	58.1	54.2	56.7	55.0	64.6	61.7	67.0	N/A	N/A
Site 10 - Portable Between Sites 1 and 7	66	60.4	60.8	60.5	56.1	56.7	56.5	57.6	62.6	67.7	N/A	N/A

*Hourly-Average Leq (dBA)

Notes recorded by the on-site Independent Noise Monitor

Work:

Design-Builder worked between 10:00pm and 7:00am to install bull rail, weld steel plates, casing delivery/unloading, install conduit, and set up for day work.

Public Comments:

11:40 p.m January 26th - A call to the hotline was received from a resident that lives in Madison Park to report construction noise from the project that was keeping him awake. He said it sounded like jackhammering. The call required a follow-up. See Public Notice Log for additional details.

Exceedances:

Site(s) 4, 9 and 10 are not project related. Exceedances are caused by public traffic driving by the noise monitors.

Non-Compliance:

None.

Legend

Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.

N/A = Time Period not applicable to MPPCNV

Red = Noise Level Exceedance, project related

Blue = Noise level exceedance, not project related

~ = No Data Available

= No contract work . Portable monitors are not being used (not needed).

SR 520 Montlake Project
Major Public Project Construction Noise Variance
NOISE MONITORING - WEEKLY REPORT
Monday, January 25, 2021 to Sunday, January 31, 2021 10 pm to 7 am (weekdays) / 9am (weekends)

The table below includes data gathered from noise monitoring equipment located at seven stationary and three portable locations throughout the Montlake Project area

Wednesday, January 27, 2021												
Site	Site limit*	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am
Site 1 - 2449 E. Lk WA Blvd	67	57.1	54.3	54.1	51.0	50.8	50.2	52.0	58.4	61.5	N/A	N/A
Site 2 - 2015 E. Roanoke St	78	60.3	58.9	57.2	56.8	55.8	56.1	58.0	61.5	64.2	N/A	N/A
Site 3A - 3810 E. McGilvra St	62	48.6	49.9	46.3	45.2	43.6	43.2	45.7	50.8	53.1	N/A	N/A
Site 4 - 2800 Montlake Blvd E	66	66.1	63.8	61.4	60.2	58.1	59.2	64.5	69.5	71.7	N/A	N/A
Site 5 - 2565 22nd Av E.	65	58.1	56.5	54.6	53.5	54.1	53.7	55.4	59.1	61.9	N/A	N/A
Site 6 - 2160 E. Hamlin St	63	53.7	49.9	51.2	46.6	49.0	48.3	49.0	56.8	56.6	N/A	N/A
Site 7 - 2209 E. Lake Wa Blvd	66	56.8	52.8	53.0	50.1	50.3	50.8	52.2	57.6	60.5	N/A	N/A
Site 8 - Portable Between Sites 4 and 6	63	57.4	54.2	51.9	50.1	50.2	48.8	50.7	57.3	57.8	N/A	N/A
Site 9 - Portable Between Sites 1 and 7	66	63.3	58.4	59.6	56.0	57.4	57.4	55.8	64.3	68.9	N/A	N/A
Site 10 - Portable Between Sites 1 and 7	66	62.0	59.4	58.0	55.8	56.9	56.0	56.6	64.5	69.0	N/A	N/A

*Hourly-Average Leq (dBA)

Notes recorded by the on-site Independent Noise Monitor

Work:

Design-Builder worked between 10:00pm and 7:00am to weld steel plates, bore/install conduit, install oak blocks on pier 1 and 2 and set up for day work.

Public Comments:

No public comments received related to nighttime noise.

Exceedances:

Site(s) 4, 9 and 10 are not project related. Exceedances are caused by public traffic driving by the noise monitors.

Non-Compliance:

None

Legend

Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.

N/A = Time Period not applicable to MPPCNV

Red = Noise Level Exceedance, project related

Blue = Noise level exceedance, not project related

~ = No Data Available

= No contract work . Portable monitors are not being used (not needed).

SR 520 Montlake Project
Major Public Project Construction Noise Variance
NOISE MONITORING - WEEKLY REPORT
Monday, January 25, 2021 to Sunday, January 31, 2021 10 pm to 7 am (weekdays) / 9am (weekends)

The table below includes data gathered from noise monitoring equipment located at seven stationary and three portable locations throughout the Montlake Project area

Thursday, January 28, 2021												
Site	Site limit*	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am
Site 1 - 2449 E. Lk WA Blvd	67	55.7	54.5	52.6	51.6	50.5	49.8	52.4	57.6	60.2	N/A	N/A
Site 2 - 2015 E. Roanoke St	78	60.6	59.6	57.0	56.5	60.9	56.0	57.5	61.6	62.8	N/A	N/A
Site 3A - 3810 E. McGilvra St	62	49.1	48.2	47.4	43.5	41.6	41.8	45.2	50.4	52.3	N/A	N/A
Site 4 - 2800 Montlake Blvd E	66	65.6	64.8	65.7	65.8	66.9	63.4	64.5	69.3	69.3	N/A	N/A
Site 5 - 2565 22nd Av E.	65	58.5	57.1	54.6	53.7	63.5	53.2	54.8	59.1	60.3	N/A	N/A
Site 6 - 2160 E. Hamlin St	63	52.6	51.1	50.5	46.2	50.0	45.2	48.8	55.2	55.4	N/A	N/A
Site 7 - 2209 E. Lake Wa Blvd	66	54.8	52.3	51.6	50.0	52.4	49.6	51.8	56.5	59.0	N/A	N/A
Site 8 - Portable Between Sites 4 and 6	63	54.6	52.8	56.3	55.9	50.5	48.0	50.6	56.6	56.7	N/A	N/A
Site 9 - Portable Between Sites 1 and 7	66	60.5	58.2	56.7	55.7	55.2	52.7	58.0	63.6	66.3	N/A	N/A
Site 10 - Portable Between Sites 1 and 7	66	61.6	59.7	57.8	57.2	55.5	54.9	58.3	64.0	67.0	N/A	N/A

*Hourly-Average Leq (dBA)

Notes recorded by the on-site Independent Noise Monitor

Work:

Design-Builder worked between 10:00pm and 7:00am to weld steel plates, bore/install conduit, install oak blocks on pier 1 and 2, crane delivery east of pier 1 and set up for day work.

Public Comments:

12:25 a.m January 28th - A call to the hotline was received from a resident that lives on Hamlin street to complain of noise and lights outside her window. She thought it was coming from the alley or from the SR 520 mainline. The call required a follow-up. **See Public Notice Log for additional details.**

Exceedances:

Site(s) 4, 9 and 10 are not project related. Exceedances are caused by public traffic driving by the noise monitors.

Non-Compliance:

3:59am Tru Line Communications was observed with a vehicle with backup alarm used multiple times throughout the night.

Legend

Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.

N/A = Time Period not applicable to MPPCNV

Red = Noise Level Exceedance, project related

Blue = Noise level exceedance, not project related

~ = No Data Available

= No contract work . Portable monitors are not being used (not needed).

SR 520 Montlake Project
Major Public Project Construction Noise Variance
NOISE MONITORING - WEEKLY REPORT

Monday, January 25, 2021 to Sunday, January 31, 2021 10 pm to 7 am (weekdays) / 9am (weekends)

The table below includes data gathered from noise monitoring equipment located at seven stationary and three portable locations throughout the Montlake Project area

Friday, January 29, 2021												
Site	Site limit*	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am
Site 1 - 2449 E. Lk WA Blvd	67	56.2	54.8	53.8	52.3	54.1	52.9	53.1	55.4	54.4	57.1	58.6
Site 2 - 2015 E. Roanoke St	78	59.8	60.0	65.2	54.9	60.3	55.5	54.5	57.3	59.6	61.0	62.2
Site 3A - 3810 E. McGilvra St	62	49.6	52.8	50.4	40.6	47.6	46.5	42.6	45.0	45.3	50.1	51.3
Site 4 - 2800 Montlake Blvd E	66	66.4	64.7	63.4	61.5	65.4	61.8	60.4	63.7	67.5	67.5	67.9
Site 5 - 2565 22nd Av E.	65	57.8	58.3	62.7	53.0	60.6	54.3	52.7	55.7	57.6	58.9	60.4
Site 6 - 2160 E. Hamlin St	63	54.6	52.7	51.9	50.6	53.2	51.9	52.1	54.7	52.1	53.6	54.9
Site 7 - 2209 E. Lake Wa Blvd	66	62.9	62.0	60.3	61.6	63.3	61.4	62.7	61.3	60.7	61.1	61.8
Site 8 - Portable Between Sites 4 and 6	63	58.8	55.4	52.1	52.5	55.9	52.4	54.2	54.8	54.2	55.1	56.1
Site 9 - Portable Between Sites 1 and 7	66	62.3	64.0	62.0	61.3	62.7	64.1	62.2	61.9	62.7	~	65.4
Site 10 - Portable Between Sites 1 and 7	66	62.7	61.9	60.0	58.8	59.5	58.4	58.0	61.6	61.8	64.1	66.4

*Hourly-Average Leq (dBA)

Notes recorded by the on-site Independent Noise Monitor

Work:

Design-Builder worked between 10:00pm and 9:00am to weld steel plates, Sawcutting of asphalt and pavement removals is covered under TNV #6820073, install girders over SR520, and set up for day work.

Public Comments:

No public comments received related to nighttime noise.

Exceedances:

Site(s) 4 and 10 are not project related. Exceedances are caused by public traffic driving by the noise monitors.

Non-Compliance:

4:58am, Graham had an equipment unlined. Eli/Gary with PBS was notified. Gary contacted Craig with Graham and he said he will track it down and shut it down and not use it until 9am. Vehicle was shut down and parked. 10:18pm, Graham had a light/stationary noise generating equipment with no temporary barriers. Temporary barriers were stationed around the equipment on the next working night.

Legend

Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.

N/A = Time Period not applicable to MPPCNV

Red = Noise Level Exceedance, project related

Blue = Noise level exceedance, not project related

~ = No Data Available

= No contract work . Portable monitors are not being used (not needed).

SR 520 Montlake Project
Major Public Project Construction Noise Variance
NOISE MONITORING - WEEKLY REPORT
Monday, January 25, 2021 to Sunday, January 31, 2021 10 pm to 7 am (weekdays) / 9am (weekends)

The table below includes data gathered from noise monitoring equipment located at seven stationary and three portable locations throughout the Montlake Project area

Saturday, January 30, 2021												
Site	Site limit*	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am
Site 1 - 2449 E. Lk WA Blvd	67	55.3	54.3	52.3	49.6	49.7	48.4	50.8	53.6	54.6	55.5	56.6
Site 2 - 2015 E. Roanoke St	78	63.9	57.9	57.7	54.2	54.5	54.0	54.4	57.6	59.4	60.5	62.2
Site 3A - 3810 E. McGilvra St	62	47.0	46.4	46.5	40.9	48.3	43.8	45.6	46.9	47.2	47.5	49.9
Site 4 - 2800 Montlake Blvd E	66	72.4	64.4	62.4	59.8	60.7	58.7	60.8	63.7	67.0	66.0	66.7
Site 5 - 2565 22nd Av E.	65	61.5	56.2	56.2	52.9	54.0	52.3	53.0	55.5	57.5	58.5	59.7
Site 6 - 2160 E. Hamlin St	63	53.4	52.2	52.0	51.2	50.7	50.3	50.9	53.1	54.1	55.2	53.8
Site 7 - 2209 E. Lake Wa Blvd	66	60.3	59.2	59.1	59.1	58.1	58.5	58.3	59.1	59.7	59.7	58.9
Site 8 - Portable Between Sites 4 and 6	63	55.6	53.4	54.7	51.7	52.1	52.0	52.1	54.7	56.0	56.0	56.2
Site 9 - Portable Between Sites 1 and 7	66	63.3	61.9	61.1	59.8	58.7	65.4	59.5	60.5	62.1	62.9	63.0
Site 10 - Portable Between Sites 1 and 7	66	62.9	61.7	57.7	55.8	54.5	53.6	56.4	58.8	60.4	61.9	63.4
*Hourly-Average Leq (dBA)												
Notes recorded by the on-site Independent Noise Monitor												
Work: Design-Builder worked between 10:00pm and 9:00am to install girders over SR520, backfill and set up for day work.												
Public Comments: No public comments received related to nighttime noise.												
Exceedances: Site(s) 4 are not project related. Exceedances are caused by public traffic driving by the noise monitors.												
Non-Compliance: None.												

Legend

Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.

N/A = Time Period not applicable to MPPCNV

Red = Noise Level Exceedance, project related

Blue = Noise level exceedance, not project related

~ = No Data Available

= No contract work . Portable monitors are not being used (not needed).

SR 520 Montlake Project
Major Public Project Construction Noise Variance
NOISE MONITORING - WEEKLY REPORT
Monday, January 25, 2021 to Sunday, January 31, 2021 10 pm to 7 am (weekdays) / 9am (weekends)

The table below includes data gathered from noise monitoring equipment located at seven stationary and three portable locations throughout the Montlake Project area

Sunday, January 31, 2021												
Site	Site limit*	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am
Site 1 - 2449 E. Lk WA Blvd	67	57.4	57.4	54.9	54.0	53.5	55.0	53.6	57.5	60.4	N/A	N/A
Site 2 - 2015 E. Roanoke St	78	58.8	59.4	57.4	57.8	56.0	57.1	59.8	62.3	64.0	N/A	N/A
Site 3A - 3810 E. McGilvra St	62	47.3	48.5	48.6	51.9	50.5	51.6	52.6	53.1	53.9	N/A	N/A
Site 4 - 2800 Montlake Blvd E	66	65.3	63.7	62.2	60.5	59.6	61.6	66.6	70.8	71.7	N/A	N/A
Site 5 - 2565 22nd Av E.	65	57.1	57.5	55.9	57.2	55.5	56.5	58.0	60.0	61.6	N/A	N/A
Site 6 - 2160 E. Hamlin St	63	57.3	51.5	49.2	48.5	50.8	48.8	51.1	55.1	57.0	N/A	N/A
Site 7 - 2209 E. Lake Wa Blvd	66	55.1	53.6	55.8	53.6	54.4	50.7	55.0	56.5	59.3	N/A	N/A
Site 8 - Portable Between Sites 4 and 6	63	54.2	52.5	49.7	49.6	52.8	49.3	52.0	56.3	58.0	N/A	N/A
Site 9 - Portable Between Sites 1 and 7	66	61.0	58.7	58.2	58.7	59.7	58.0	67.1	64.0	67.1	N/A	N/A
Site 10 - Portable Between Sites 1 and 7	66	61.7	61.1	57.5	57.5	59.3	58.6	59.1	64.4	67.3	N/A	N/A

*Hourly-Average Leq (dBA)

Notes recorded by the on-site Independent Noise Monitor

Work:
Design-Builder worked between 10:00pm and 4:00am to complete the weekend girder installation work, and set up for day work.

Public Comments:
No public comments received related to nighttime noise.

Exceedances:
Site(s) 4, 9 and 10 are not project related. Exceedances are caused by public traffic driving by the noise monitors.

Non-Compliance:
None.

Legend

Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.

N/A = Time Period not applicable to MPPCNV

Red = Noise Level Exceedance, project related

Blue = Noise level exceedance, not project related

~ = No Data Available

= No contract work . Portable monitors are not being used (not needed).

SR 520 Montlake Project
Major Public Project Construction Noise Variance
NOISE MONITORING - WEEKLY REPORT

Monday, January 25, 2021 to Sunday, January 31, 2021

10 p.m. to 7 a.m. (weekdays)/9a.m. (weekends)

Public Comment Log			
Date / Time	To/From	Issue	Resolution
01/26/2021 - 11:40pm	To: Hotline From: Resident in Madison Park	During the MPPCNV Monitoring: Resident called the project hotline at 11:40 p.m. to report construction noise from the project that was keeping him awake. He said it sounded like jackhammering. Resident requested that Bob not call him back directly that night but to leave the information on his office voicemail.	Bob Derry (Public Information Manager) answered the hotline call and called the resident on 1/27 at 12:27am and left him a message letting him know that the noise was within our approved noise operating levels and that it would continue for another week. Bob called Zack again at 8:44 a.m. on 1/27 and left a voice mail asking how the rest of his night went.
01/28/2021 - 12:25am	To: Hotline From: Resident on Hamlin Street	During the MPPCNV Monitoring: Resident called the project hotline at 11:40 p.m. to complain of noise and lights outside her window. She thought it was coming from the alley or from the SR 520 mainline. She reported that men were yelling to each other, engines were revving, and blinking lights were shining into her bedroom window. This had been going on for a long time, and it was disturbing her family's sleep.	Bob Derry (Public Information Manager) answered the hotline call and called the resident on 1/29 at 12:53am and notified resident that True Line is not one of the project's sub-contractors. He reported that Graham told the True Line crews about Montlake Project noise requirements and asked them to stop yelling and to use their walkie talkies to communicate. Tru Line said they would not turn off their lights. Bob Derry ask the resident if she wanted a hotel for the night. She said it was too late to move to a hotel and requested if nighttime work like this was going to occur in the future that they be given a warning about it.