

SR 520 Montlake Project

Noise Monitoring Weekly Report Summary for **Monday, February 14, 2022** to **Sunday, February 20, 2022**

PUBLISHED February 23rd, 2022

Monitoring times: Weekdays, 10 p.m. to 7 a.m.; weekends, 10 p.m. to 9 a.m.

How to use this report: This document summarizes the weekly nighttime noise data for the SR 520 Montlake Project. In it, you'll find:

- Page 1 - Summary of noise levels recorded above the limits allowed under the Major Public Project Construction Noise Variance, for this week and throughout the project. This includes non -project-related noise exceedances
- Page 2 - Map of the project limits and locations of the seven stationary monitor locations
- Pages 3 – 9 - Night -by-night noise recordings for each of the project noise monitors, along with a description of the work that night, comments received from the public regarding Project noise, and explanations for any noise limit exceedances and actions taken in response
- Page 10 - Log of public comments regarding nighttime noise issues and resolutions for the week

WSDOT is sharing this information as per the terms of the Major Public Project Construction Noise Variance (Permit #3030792).

MPPCNV start date: Friday, August 16, 2019

MPPCNV days to date: 920

WEEKLY TOTALS	
Nights worked this week (under the MPPCNV)	4
Project related non-compliance this week	0
Nighttime noise issue comments to the project	0
Non-project-related noise exceedances this week	20

PROJECT TOTALS TO DATE	
Total Nights Worked (under the MPPCNV)	450
Total Project related non-compliance	113
Total noise issue comments to the project	113
Total non-project related exceedances	3407

Noise Monitoring Locations: the map below shows the work limits of the SR 520 Montlake Project and the locations of the seven stationary noise monitoring sites

EXHIBIT 5. CONSTRUCTION AREA AND NOISE MEASUREMENT LOCATIONS



SR 520 Montlake Project
Major Public Project Construction Noise Variance
NOISE MONITORING - WEEKLY REPORT
Monday, February 14, 2022 to Sunday, February 20, 2022 10 pm to 7 am (weekdays) / 9am (weekends)

The table below includes data gathered from noise monitoring equipment located at seven stationary and three portable locations throughout the Montlake Project area

Monday, February 14, 2022												
Site	Site limit*	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am
Site 1 -2449 E. Lk WA Blvd	67	56.2	54.0	51.1	49.1	49.5	51.1	51.2	55.3	58.5	N/A	N/A
Site 2 - 2015 E. Roanoke St	78	60.8	58.1	54.8	52.7	51.2	53.8	54.6	58.9	62.6	N/A	N/A
Site 3A - Canterbury Shores	62	51.8	48.4	44.3	41.0	41.7	44.4	44.2	49.2	52.3	N/A	N/A
Site 4 - 2800 Montlake Blvd E	66	65.1	62.7	59.8	56.9	56.7	58.7	62.5	66.5	69.2	N/A	N/A
Site 5 - 2565 22nd Av E.	65	59.4	56.9	53.3	50.9	49.8	52.4	52.6	56.8	61.3	N/A	N/A
Site 6 - 2160 E. Hamlin St	63	53.5	53.1	52.6	47.0	48.0	50.2	50.0	53.7	55.8	N/A	N/A
Site 7 - 2209 E. Lake Wa Blvd	66	54.3	52.0	48.8	45.9	45.3	48.1	51.0	53.2	56.7	N/A	N/A
Site 8 - Portable Between Sites 4 and 6	63	56.6	55.8	52.1	49.4	49.0	51.9	51.9	55.8	58.4	N/A	N/A
Site 9 - Portable Between Sites 1 and 7	66	61.9	59.0	56.5	52.7	52.7	55.1	58.9	61.0	64.2	N/A	N/A
Site 10 - Portable Between Sites 1 and 7	66	62	59.1	55.9	54.1	54.8	56.1	58.1	62.9	66	N/A	N/A

*Hourly-Average Leq (dBA)

Notes recorded by the on-site Independent Noise Monitor

Work:

Design-Builder worked between 10:00 p.m. and 3:50 a.m. installing underlid lighting under the Montlake bridge lid.

Public Comments:

No public comments received related to nighttime noise.

Exceedances:

Sites 4, & 10 exceedances are due to public traffic. **(Non work related).**

Non-Compliance:

None.

Legend

Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.

N/A = Time Period not applicable to MPPCNV

Red = Noise Level Exceedance, project related

Blue = Noise level exceedance, not project related

~ = No Data Available

= No contract work . Portable monitors are not being used (not needed).

SR 520 Montlake Project
Major Public Project Construction Noise Variance
NOISE MONITORING - WEEKLY REPORT

Monday, February 14, 2022 to Sunday, February 20, 2022 10 pm to 7 am (weekdays) / 9am (weekends)

The table below includes data gathered from noise monitoring equipment located at seven stationary and three portable locations throughout the Montlake Project area

Tuesday, February 15, 2022												
Site	Site limit*	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am
Site 1 - 2449 E. Lk WA Blvd	67	53.7	52.1	48.7	49.5	48.7	50.5	52.2	56.5	58.8	N/A	N/A
Site 2 - 2015 E. Roanoke St	78	59.3	57.6	54.5	53.2	52.8	53.9	57.1	60.0	63.5	N/A	N/A
Site 3A - Canterbury Shores	62	49.8	48.8	45.6	43.6	42.5	44.2	47.8	52.4	55.4	N/A	N/A
Site 4 - 2800 Montlake Blvd E	66	64.9	62.7	59.3	57.5	55.8	58.2	62.7	66.5	71.2	N/A	N/A
Site 5 - 2565 22nd Av E.	65	58.0	56.0	52.7	51.5	51.8	52.0	55.4	58.1	61.9	N/A	N/A
Site 6 - 2160 E. Hamlin St	63	52.4	51.1	47.1	44.0	46.5	46.4	46.5	49.1	53.3	N/A	N/A
Site 7 - 2209 E. Lake Wa Blvd	66	52.1	50.5	46.7	45.2	46.7	47.2	50.0	53.6	57.9	N/A	N/A
Site 8 - Portable Between Sites 4 and 6	63	54.7	53.0	49.0	46.2	49.2	49.4	51.0	52.8	58.0	N/A	N/A
Site 9 - Portable Between Sites 1 and 7	66	60.4	59.1	55.1	53.0	57.1	54.4	58.4	61.3	66.8	N/A	N/A
Site 10 - Portable Between Sites 1 and 7	66	61.0	59.5	54.2	55.6	53.2	56.3	58.0	63.2	65.9	N/A	N/A

*Hourly-Average Leq (dBA)

Notes recorded by the on-site Independent Noise Monitor

Work:

Design-Builder worked between 10:00 p.m. and 3:29am on installation of Hangar assemblies and conduit and the cleaning and labeling of units under the Montlake lid

Public Comments:

No public comments received related to nighttime noise.

Exceedances:

Sites 4, & 9 exceedances are due to public traffic. **(Non work related).**

Non-Compliance:

None.

Legend

Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.

N/A = Time Period not applicable to MPPCNV

Red = Noise Level Exceedance, project related

Blue = Noise level exceedance, not project related

~ = No Data Available

= No contract work . Portable monitors are not being used (not needed).

SR 520 Montlake Project
Major Public Project Construction Noise Variance
NOISE MONITORING - WEEKLY REPORT

Monday, February 14, 2022 to Sunday, February 20, 2022 10 pm to 7 am (weekdays) / 9am (weekends)

The table below includes data gathered from noise monitoring equipment located at seven stationary and three portable locations throughout the Montlake Project area

Wednesday, February 16, 2022												
Site	Site limit*	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am
Site 1 - 2449 E. Lk WA Blvd	67	58.3	54.4	51.9	49	49.9	50.2	51.9	55.6	57.7	N/A	N/A
Site 2 - 2015 E. Roanoke St	78	60.4	58.2	54	51.4	52.7	52.7	55.3	69	61.3	N/A	N/A
Site 3A - Canterbury Shores	62	49.9	48.1	43.7	42.5	43.6	43.4	46.5	50.8	52.5	N/A	N/A
Site 4 - 2800 Montlake Blvd E	66	65.2	62.6	59.8	57.6	56.4	58.7	63.2	69.9	69	N/A	N/A
Site 5 - 2565 22nd Av E.	65	58.8	56.8	52.8	50	51	51	54	70.3	60.4	N/A	N/A
Site 6 - 2160 E. Hamlin St	63	58.9	53.5	51.6	46.5	47.5	48.2	51.5	56.1	57	N/A	N/A
Site 7 - 2209 E. Lake Wa Blvd	66	56.1	52.4	49.4	46.1	47	48.1	49.8	55.6	56	N/A	N/A
Site 8 - Portable Between Sites 4 and 6	63	59.7	55.5	53	48.8	49.7	49.5	53.3	59.5	58.5	N/A	N/A
Site 9 - Portable Between Sites 1 and 7	66	61.9	58.8	54.6	53	55.9	56.3	58.3	62.5	63.7	N/A	N/A
Site 10 - Portable Between Sites 1 and 7	66	63.9	59.6	56.7	54	56.5	56.9	57.4	62.6	65.5	N/A	N/A

*Hourly-Average Leq (dBA)

Notes recorded by the on-site Independent Noise Monitor

Work:

Design-Builder worked between 10:00pm and 3:32am on installation of Hangar assemblies and conduit and cleaning and labeling of units under the Montlake lid

Public Comments:

No public comments received related to nighttime noise.

Exceedances:

Sites 4, & 5 exceedances are due to public traffic. **(Non work related).**

Non-Compliance:

None

Legend

Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.

N/A = Time Period not applicable to MPPCNV

Red = Noise Level Exceedance, project related

Blue = Noise level exceedance, not project related

~ = No Data Available

= No contract work . Portable monitors are not being used (not needed).

SR 520 Montlake Project
Major Public Project Construction Noise Variance
NOISE MONITORING - WEEKLY REPORT

Monday, February 14, 2022 to Sunday, February 20, 2022 10 pm to 7 am (weekdays) / 9am (weekends)

The table below includes data gathered from noise monitoring equipment located at seven stationary and three portable locations throughout the Montlake Project area

Thursday, February 17, 2022												
Site	Site limit*	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am
Site 1 - 2449 E. Lk WA Blvd	67	54.6	52.5	51.3	48.3	49.1	50.9	52.0	56.3	59.2	N/A	N/A
Site 2 - 2015 E. Roanoke St	78	58.2	56.6	54.9	52.1	52.1	52.2	55.0	59.1	61.4	N/A	N/A
Site 3A - Canterbury Shores	62	49.0	47.1	45.0	43.0	44.2	42.0	45.4	50.1	53.6	N/A	N/A
Site 4 - 2800 Montlake Blvd E	66	64.9	62.1	59.8	57.8	57.4	60.6	62.4	66.6	68.7	N/A	N/A
Site 5 - 2565 22nd Av E.	65	56.5	55.2	53.5	50.5	51.4	50.7	53.3	57.2	59.8	N/A	N/A
Site 6 - 2160 E. Hamlin St	63	52.3	51.9	50.9	48.2	49.1	48.3	48.6	50.7	54.0	N/A	N/A
Site 7 - 2209 E. Lake Wa Blvd	66	52.2	50.4	49.0	46.0	46.6	48.7	49.6	53.4	56.3	N/A	N/A
Site 8 - Portable Between Sites 4 and 6	63	54.2	54.2	52.9	49.9	50.8	50.3	51.9	53.7	56.7	N/A	N/A
Site 9 - Portable Between Sites 1 and 7	66	58.7	57.5	55.3	53.1	53.3	58.3	57.6	60.3	63.1	N/A	N/A
Site 10 - Portable Between Sites 1 and 7	66	61.4	58.6	56.3	52.5	53.4	57.9	58.3	62.4	65.8	N/A	N/A

*Hourly-Average Leq (dBA)

Notes recorded by the on-site Independent Noise Monitor

Work:

Design-Builder worked between 10:00pm and 3:28am on installation of Hangar assemblies and conduit and cleaning and labeling of units under the Montlake lid

Public Comments:

No public comments received related to nighttime noise.

Exceedances:

Site(s) 4, exceedances are due to public traffic driving by the noise monitors (**not work related**).

Non-Compliance:

None

Legend

Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.

N/A = Time Period not applicable to MPPCNV

Red = Noise Level Exceedance, project related

Blue = Noise level exceedance, not project related

~ = No Data Available

= No contract work . Portable monitors are not being used (not needed).

SR 520 Montlake Project
Major Public Project Construction Noise Variance
NOISE MONITORING - WEEKLY REPORT

Monday, February 14, 2022 to Sunday, February 20, 2022 10 pm to 7 am (weekdays) / 9am (weekends)

The table below includes data gathered from noise monitoring equipment located at seven stationary and three portable locations throughout the Montlake Project area

Friday, February 18, 2022												
Site	Site limit*	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am
Site 1 - 2449 E. Lk WA Blvd	67	56.3	54.1	54.8	49.9	47.9	45.8	47.5	49.5	52.5	54.6	56.9
Site 2 - 2015 E. Roanoke St	78	60.4	59.5	57.8	56.2	55.3	52.6	52.0	55.2	58.2	59.8	61.1
Site 3A - Canterbury Shores	62	49.8	48.5	45.6	44.9	43.9	42.6	39.4	46.8	50.4	49.7	51.8
Site 4 - 2800 Montlake Blvd E	66	66.0	63.7	62.6	66.1	63.3	57.6	56.8	63.0	66.0	66.5	67.8
Site 5 - 2565 22nd Av E.	65	58.9	57.9	55.9	54.9	53.4	50.9	50.5	53.8	56.9	58.4	59.7
Site 6 - 2160 E. Hamlin St	63	52.9	53.4	50.5	49.9	49.2	45.9	44.8	48.8	53.0	54.1	56.5
Site 7 - 2209 E. Lake Wa Blvd	66	54.2	52.5	51.3	48.6	47.8	45.0	44.4	48.5	51.9	53.4	55.3
Site 8 - Portable Between Sites 4 and 6	63	55.2	55.5	53.7	52.3	50.7	47.9	47.3	51.1	55	56.1	57.8
Site 9 - Portable Between Sites 1 and 7	66	60.8	60.2	60.0	55.6	55.7	52.7	52.7	57.5	59.7	61.5	62.9
Site 10 - Portable Between Sites 1 and 7	66	63.3	60.7	62.5	56.5	54.4	51.6	53.4	57.4	59.8	63.1	65.8

*Hourly-Average Leq (dBA)

Notes recorded by the on-site Independent Noise Monitor

Work:

No nighttime construction work performed.

Public Comments:

No public comments received related to nighttime noise.

Exceedances:

Site(s) 4 exceedances are due to public traffic driving by the noise monitors (**not work related**).

Non-Compliance:

None

Legend

Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.

N/A = Time Period not applicable to MPPCNV

Red = Noise Level Exceedance, project related

Blue = Noise level exceedance, not project related

~ = No Data Available

= No contract work . Portable monitors are not being used (not needed).

SR 520 Montlake Project
Major Public Project Construction Noise Variance
NOISE MONITORING - WEEKLY REPORT
Monday, February 14, 2022 to Sunday, February 20, 2022 10 pm to 7 am (weekdays) / 9am (weekends)

The table below includes data gathered from noise monitoring equipment located at seven stationary and three portable locations throughout the Montlake Project area

Saturday, February 19, 2022												
Site	Site limit*	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am
Site 1 - 2449 E. Lk WA Blvd	67	54.1	51.7	50.2	46.3	45.2	44.7	47.3	54.4	56.5	59.7	60.5
Site 2 - 2015 E. Roanoke St	78	60.7	59.7	57.9	56	55.1	55.5	53	57.4	59.2	58.5	59.5
Site 3A - Canterbury Shores	62	51.4	50.0	48.6	45.3	45.1	49.4	43.5	48.8	48.5	48.5	49.4
Site 4 - 2800 Montlake Blvd E	66	65.3	64.4	62.3	60.9	59.9	60.2	58.5	64.0	66.8	66.0	66.3
Site 5 - 2565 22nd Av E.	65	59.0	58.2	56.6	54.3	53.4	55.5	51.7	57.0	57.6	57.0	58.0
Site 6 - 2160 E. Hamlin St	63	54.0	53.2	51.6	48.4	47.1	48.6	46.8	49.3	53.3	55.2	55.9
Site 7 - 2209 E. Lake Wa Blvd	66	53.6	51.3	49.4	46.7	44.3	45.6	46.9	53.4	55.6	58.1	57.7
Site 8 - Portable Between Sites 4 and 6	63	55.9	55.4	53.1	50.3	49.5	50.4	50.1	51.6	55.2	56.8	57.1
Site 9 - Portable Between Sites 1 and 7	66	61.6	61.1	58.3	56.9	56.0	55.8	55.0	60.1	61.6	61.1	63.5
Site 10 - Portable Between Sites 1 and 7	66	62.8	60.8	58.5	56.0	53.8	55.5	53.8	59.1	59.7	61.5	64.7

*Hourly-Average Leq (dBA)

Notes recorded by the on-site Independent Noise Monitor

Work:

No nighttime construction work performed.

Public Comments:

No public comments received related to nighttime noise.

Exceedances:

Site(s) 4 exceedances are due to public traffic driving by the noise monitors (not work related).

Non-Compliance:

None

Legend

Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.

N/A = Time Period not applicable to MPPCNV

Red = Noise Level Exceedance, project related

Blue = Noise level exceedance, not project related

~ = No Data Available

= No contract work . Portable monitors are not being used (not needed).

SR 520 Montlake Project
Major Public Project Construction Noise Variance
NOISE MONITORING - WEEKLY REPORT
Monday, February 14, 2022 to Sunday, February 20, 2022 10 pm to 7 am (weekdays) / 9am (weekends)

The table below includes data gathered from noise monitoring equipment located at seven stationary and three portable locations throughout the Montlake Project area

Sunday, February 20, 2022												
Site	Site limit*	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am
Site 1 -2449 E. Lk WA Blvd	67	54.1	51.7	50.2	46.3	45.2	44.7	47.3	54.4	56.5	N/A	N/A
Site 2 - 2015 E. Roanoke St	78	58.8	57.2	55.2	54.4	50.0	51.0	53.0	57.8	60.9	N/A	N/A
Site 3A - Canterbury Shores	62	48.0	46.0	44.8	41.3	40.5	40.1	42.9	48.3	50.1	N/A	N/A
Site 4 - 2800 Montlake Blvd E	66	64.4	62.9	61.1	63.5	55.5	57.5	60.4	65.6	68.6	N/A	N/A
Site 5 - 2565 22nd Av E.	65	57.2	55.9	53.8	53.3	48.9	49.2	51.2	56.1	59.0	N/A	N/A
Site 6 - 2160 E. Hamlin St	63	53.8	52.0	50.7	47.5	47.9	47.4	48.3	53.2	52.9	N/A	N/A
Site 7 - 2209 E. Lake Wa Blvd	66	49.9	48.5	45.3	41.8	42.5	45.7	49.7	53.0	55.0	N/A	N/A
Site 8 - Portable Between Sites 4 and 6	63	55.8	54.6	53.5	50.1	49.2	48.4	50.7	55.8	55.9	N/A	N/A
Site 9 - Portable Between Sites 1 and 7	66	61.2	59.1	56.4	54.6	50.1	53.3	55.0	61.4	64.5	N/A	N/A
Site 10 - Portable Between Sites 1 and 7	66	61.6	58.4	55.6	52.5	49.8	51.5	54.3	61.8	64.6	N/A	N/A

*Hourly-Average Leq (dBA)

Notes recorded by the on-site Independent Noise Monitor

Work:

No nighttime construction work performed.

Public Comments:

No public comments received related to nighttime noise.

Exceedances:

Site(s) 4 exceedance is due to public traffic driving by the noise monitors (not work related).

Non-Compliance:

None

Legend

Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.

N/A = Time Period not applicable to MPPCNV

Red = Noise Level Exceedance, project related

Blue = Noise level exceedance, not project related

~ = No Data Available

= No contract work . Portable monitors are not being used (not needed).

SR 520 Montlake Project
Major Public Project Construction Noise Variance
NOISE MONITORING - WEEKLY REPORT

Monday, February 14, 2022 to Sunday, February 20, 2022

10 p.m. to 7 a.m. (weekdays)/9a.m. (weekends)

Public Comment Log			
Date / Time	To/From	Issue	Resolution
		No noise related complains	