

## SR 520 Montlake Project

Noise Monitoring Weekly Report Summary for **Monday, March 7, 2022** to **Sunday, March 13, 2022**

PUBLISHED March 16th, 2022

Monitoring times: Weekdays, 10 p.m. to 7 a.m.; weekends, 10 p.m. to 9 a.m.

**How to use this report:** This document summarizes the weekly nighttime noise data for the SR 520 Montlake Project. In it, you'll find:

- Page 1 - Summary of noise levels recorded above the limits allowed under the Major Public Project Construction Noise Variance, for this week and throughout the project. This includes non -project-related noise exceedances
- Page 2 - Map of the project limits and locations of the seven stationary monitor locations
- Pages 3 – 9 - Night -by-night noise recordings for each of the project noise monitors, along with a description of the work that night, comments received from the public regarding Project noise, and explanations for any noise limit exceedances and actions taken in response
- Page 10 - Log of public comments regarding nighttime noise issues and resolutions for the week

WSDOT is sharing this information as per the terms of the Major Public Project Construction Noise Variance (Permit #3030792).

MPPCNV start date: **Friday, August 16, 2019**

MPPCNV days to date: **941**

WEEKLY TOTALS	
Nights worked this week (under the MPPCNV)	4
Project related non-compliance this week	0
Nighttime noise issue comments to the project	0
Non-project-related noise exceedances this week	24

PROJECT TOTALS TO DATE	
Total Nights Worked (under the MPPCNV)	462
Total Project related non-compliance	113
Total noise issue comments to the project	113
Total non-project related exceedances	3489

**Noise Monitoring Locations:** the map below shows the work limits of the SR 520 Montlake Project and the locations of the seven stationary noise monitoring sites

**EXHIBIT 5. CONSTRUCTION AREA AND NOISE MEASUREMENT LOCATIONS**



**SR 520 Montlake Project**  
**Major Public Project Construction Noise Variance**  
**NOISE MONITORING - WEEKLY REPORT**  
**Monday, March 7, 2022 to Sunday, March 13, 2022 10 pm to 7 am (weekdays) / 9am (weekends)**

The table below includes data gathered from noise monitoring equipment located at seven stationary and three portable locations throughout the Montlake Project area

<b>Monday, March 7, 2022</b>												
Site	Site limit*	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am
Site 1 -2449 E. Lk WA Blvd	67	51.0	49.8	46.3	45.6	42.6	44.5	47.9	52.1	55.5	N/A	N/A
Site 2 - 2015 E. Roanoke St	78	58.9	57.9	55.9	52.7	55.5	56.3	56.0	60.8	63.6	N/A	N/A
Site 3A - Canterbury Shores	62	50.1	48.7	45.9	44.3	41.8	43.4	47.0	51.5	53.7	N/A	N/A
Site 4 - 2800 Montlake Blvd E	66	64.2	62.8	59.4	56.1	60.7	59.2	64.0	68.2	71.1	N/A	N/A
Site 5 - 2565 22nd Av E.	65	57.9	57.0	55.1	52.0	54.0	54.1	54.3	59.2	61.8	N/A	N/A
Site 6 - 2160 E. Hamlin St	63	56.9	55.2	52.2	47.0	46.6	47.3	48.3	52.0	56.6	N/A	N/A
Site 7 - 2209 E. Lake Wa Blvd	66	50.0	48.3	45.0	41.1	43.7	47.4	47.9	51.8	56.8	N/A	N/A
Site 8 - Portable Between Sites 4 and 6	63	58.0	56.4	53.3	48.1	49.4	50.6	52.0	55.1	58.7	N/A	N/A
Site 9 - Portable Between Sites 1 and 7	66	59.3	58.7	56.9	51.1	57.3	64.1	58.0	63.6	67.4	N/A	N/A
Site 10 - Portable Between Sites 1 and 7	66	62.1	59.7	59	55.5	53	55.4	60.3	65.2	68.5	N/A	N/A

\*Hourly-Average Leq (dBA)

**Notes recorded by the on-site Independent Noise Monitor**

**Work:**

Design-Builder worked between 10:00pm and 3:46am on installing emergency/maintenance boxes

**Public Comments:**

No public comments received related to nighttime noise.

**Exceedances:**

Sites 4, & 10 exceedances are due to public traffic. **(Non work related).**

**Non-Compliance:**

None.

**Legend**

Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.

N/A = Time Period not applicable to MPPCNV

Red = Noise Level Exceedance, project related

Blue = Noise level exceedance, not project related

~ = No Data Available

# = No contract work . Portable monitors are not being used (not needed).

**SR 520 Montlake Project**  
**Major Public Project Construction Noise Variance**  
**NOISE MONITORING - WEEKLY REPORT**  
**Monday, March 7, 2022 to Sunday, March 13, 2022 10 pm to 7 am (weekdays) / 9am (weekends)**

The table below includes data gathered from noise monitoring equipment located at seven stationary and three portable locations throughout the Montlake Project area

<b>Tuesday, March 8, 2022</b>												
Site	Site limit*	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am
Site 1 -2449 E. Lk WA Blvd	67	52.0	49.9	46.1	44.1	42.3	44.5	48.4	53.2	56.4	N/A	N/A
Site 2 - 2015 E. Roanoke St	78	61.4	58.8	56.6	56.2	55.2	55.6	56.1	59.8	63.4	N/A	N/A
Site 3A - Canterbury Shores	62	51.0	49.6	46.7	43.0	42.8	42.8	46.1	51.0	55.0	N/A	N/A
Site 4 - 2800 Montlake Blvd E	66	64.7	63.8	59.8	57.3	58.0	58.8	63.2	66.3	69.1	N/A	N/A
Site 5 - 2565 22nd Av E.	65	59.4	56.4	53.5	53.4	52.2	53.8	54.3	57.7	61.4	N/A	N/A
Site 6 - 2160 E. Hamlin St	63	55.7	53.1	49.0	42.2	46.4	44.9	45.7	49.8	55.2	N/A	N/A
Site 7 - 2209 E. Lake Wa Blvd	66	50.0	47.8	44.3	43.0	41.3	44.3	47.8	50.8	54.1	N/A	N/A
Site 8 - Portable Between Sites 4 and 6	63	57.3	55.3	52.1	47.7	49.7	48.8	50.8	53.6	58.2	N/A	N/A
Site 9 - Portable Between Sites 1 and 7	66	60.0	57.1	55.2	55.0	52.7	55.3	57.5	59.7	63.9	N/A	N/A
Site 10 - Portable Between Sites 1 and 7	66	63.9	60.1	57.5	55.3	54.3	56.9	59.4	63.6	67.2	N/A	N/A

\*Hourly-Average Leq (dBA)

**Notes recorded by the on-site Independent Noise Monitor**

**Work:**  
 Design-Builder worked between 10:00pm and 3:36am on installing emergency/maintenance boxes, and transverse bracing

**Public Comments:**  
 No public comments received related to nighttime noise.

**Exceedances:**  
 Sites 4, 10 exceedances are due to public traffic. **(Non work related).**

**Non-Compliance:**  
 None.

**Legend**  
 Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.  
 N/A = Time Period not applicable to MPPCNV  
 Red = Noise Level Exceedance, project related  
 Blue = Noise level exceedance, not project related  
 ~ = No Data Available  
 # = No contract work . Portable monitors are not being used (not needed).

**SR 520 Montlake Project**  
**Major Public Project Construction Noise Variance**  
**NOISE MONITORING - WEEKLY REPORT**  
**Monday, March 7, 2022 to Sunday, March 13, 2022 10 pm to 7 am (weekdays) / 9am (weekends)**

The table below includes data gathered from noise monitoring equipment located at seven stationary and three portable locations throughout the Montlake Project area

<b>Wednesday, March 9, 2022</b>												
Site	Site limit*	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am
Site 1 -2449 E. Lk WA Blvd	67	54	51.1	48.7	46.7	46.4	47.9	50.3	54.6	57.7	N/A	N/A
Site 2 - 2015 E. Roanoke St	78	61	60	57.7	56.3	55.8	56.4	56.4	59.7	63.2	N/A	N/A
Site 3A - Canterbury Shores	62	51.6	48.8	47.2	43.6	43.1	43.7	47.6	51.9	54.6	N/A	N/A
Site 4 - 2800 Montlake Blvd E	66	65.1	62.6	60.8	57.8	57.5	58.9	62.9	67	69.7	N/A	N/A
Site 5 - 2565 22nd Av E.	65	59	57.6	55.4	53.7	52.9	54	54.4	57.6	61.5	N/A	N/A
Site 6 - 2160 E. Hamlin St	63	55.4	55.1	52.6	50.7	48.4	49	52	57.1	57.8	N/A	N/A
Site 7 - 2209 E. Lake Wa Blvd	66	51.4	49.3	46.2	43.9	44.3	47.8	49.1	52.3	54.8	N/A	N/A
Site 8 - Portable Between Sites 4 and 6	63	58	56.4	54.5	51.5	50.4	51.6	54.5	59.2	58.1	N/A	N/A
Site 9 - Portable Between Sites 1 and 7	66	60.1	59.8	56	53.7	54.8	57.1	57.7	61.4	63.9	N/A	N/A
Site 10 - Portable Between Sites 1 and 7	66	65.4	61.8	58.9	55.6	57.1	57	60.8	64.6	67.7	N/A	N/A

\*Hourly-Average Leq (dBA)

**Notes recorded by the on-site Independent Noise Monitor**

**Work:**  
 Design-Builder worked between 10:00pm and 3:34am on installing emergency/maintenance boxes, and transverse bracing

**Public Comments:**  
 No public comments received related to nighttime noise.

**Exceedances:**  
 Sites 4, & 10 exceedances are due to public traffic. **(Non work related).**

**Non-Compliance:**  
 None

**Legend**  
 Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.  
 N/A = Time Period not applicable to MPPCNV  
 Red = Noise Level Exceedance, project related  
 Blue = Noise level exceedance, not project related  
 ~ = No Data Available  
 # = No contract work . Portable monitors are not being used (not needed).

**SR 520 Montlake Project**  
**Major Public Project Construction Noise Variance**  
**NOISE MONITORING - WEEKLY REPORT**  
**Monday, March 7, 2022 to Sunday, March 13, 2022 10 pm to 7 am (weekdays) / 9am (weekends)**

The table below includes data gathered from noise monitoring equipment located at seven stationary and three portable locations throughout the Montlake Project area

<b>Thursday, March 10, 2022</b>												
Site	Site limit*	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am
Site 1 -2449 E. Lk WA Blvd	67	53.2	52.1	48.3	46.5	44.3	46.0	47.1	52.9	56.2	N/A	N/A
Site 2 - 2015 E. Roanoke St	78	59.1	58.2	58.8	52.9	58.1	52.8	55.4	58.8	62.5	N/A	N/A
Site 3A - Canterbury Shores	62	49.9	47.6	43.8	42.6	43.9	43.4	46.7	49.6	53.7	N/A	N/A
Site 4 - 2800 Montlake Blvd E	66	64.6	64.9	61.5	57.6	58.7	58.6	62.5	66.4	68.7	N/A	N/A
Site 5 - 2565 22nd Av E.	65	57.7	56.9	56.8	51.5	57.8	52.5	53.6	56.8	60.6	N/A	N/A
Site 6 - 2160 E. Hamlin St	63	55.0	54.3	52.1	50.0	47.0	46.5	48.7	51.4	55.0	N/A	N/A
Site 7 - 2209 E. Lake Wa Blvd	66	50.5	54.1	46.2	44.4	45.9	44.4	45.6	52.1	54.2	N/A	N/A
Site 8 - Portable Between Sites 4 and 6	63	58.1	56.4	53.0	51.9	50.1	48.8	52.2	54.6	58.6	N/A	N/A
Site 9 - Portable Between Sites 1 and 7	66	59.4	64.9	61.0	53.5	61.4	55.1	56.1	61.9	63.7	N/A	N/A
Site 10 - Portable Between Sites 1 and 7	66	64.4	66.5	59.6	56.3	55.8	56.5	57.3	63.7	66.8	N/A	N/A

\*Hourly-Average Leq (dBA)

**Notes recorded by the on-site Independent Noise Monitor**

**Work:**

Design-Builder worked between 10:00pm and 3:30am on installing emergency/maintenance boxes, and transverse bracing. Design-Builder moved crane to work site from 4:20am to 5:59am.

**Public Comments:**

No public comments received related to nighttime noise.

**Exceedances:**

Site(s) 4, 10 exceedances are due to public traffic driving by the noise monitors (**not work related**).

**Non-Compliance:**

None

**Legend**

Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.

N/A = Time Period not applicable to MPPCNV

Red = Noise Level Exceedance, project related

Blue = Noise level exceedance, not project related

~ = No Data Available

# = No contract work . Portable monitors are not being used (not needed).

**SR 520 Montlake Project**  
**Major Public Project Construction Noise Variance**  
**NOISE MONITORING - WEEKLY REPORT**  
Monday, March 7, 2022 to Sunday, March 13, 2022 10 pm to 7 am (weekdays) / 9am (weekends)

The table below includes data gathered from noise monitoring equipment located at seven stationary and three portable locations throughout the Montlake Project area

<b>Friday, March 11, 2022</b>												
Site	Site limit*	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am
Site 1 -2449 E. Lk WA Blvd	67	48.9	50.7	47.5	47.9	45.7	43.9	43.1	46.1	49.5	50.5	55.0
Site 2 - 2015 E. Roanoke St	78	61.2	60.8	59.0	55.9	61.3	51.8	52.0	54.6	57.5	59.0	61.1
Site 3A - Canterbury Shores	62	52.0	49.2	49.6	45.8	44.7	41.7	42.1	44.1	52.2	51.4	54.1
Site 4 - 2800 Montlake Blvd E	66	65.4	64.0	62.3	60.6	62.9	69.1	58.9	61.3	65.4	66.0	66.8
Site 5 - 2565 22nd Av E.	65	59.3	59.1	57.4	53.9	58.7	50.0	50.4	53.0	55.8	57.8	59.4
Site 6 - 2160 E. Hamlin St	63	53.7	51.9	51.4	54.0	52.6	50.1	48.9	50.1	55.4	55.0	53.1
Site 7 - 2209 E. Lake Wa Blvd	66	49.2	49.8	46.9	46.7	51.8	42.5	42.9	45.7	49.0	50.5	52.0
Site 8 - Portable Between Sites 4 and 6	63	55.4	54.8	53.0	54.7	56.7	51.8	49.9	52.4	58.3	57.3	57.5
Site 9 - Portable Between Sites 1 and 7	66	61.0	59.8	57.9	57.5	54.2	68.6	53.6	55.1	57.9	60.5	61.6
Site 10 - Portable Between Sites 1 and 7	66	62.2	62.4	59.5	61.4	55.0	53.6	54.3	56.9	60.3	63.7	66.4

\*Hourly-Average Leq (dBA)

**Notes recorded by the on-site Independent Noise Monitor**

**Work:**

No nighttime construction work performed.

**Public Comments:**

No public comments received related to nighttime noise.

**Exceedances:**

Site(s) 4, 9, & 10 exceedances are due to public traffic driving by the noise monitors (**not work related**).

**Non-Compliance:**

None

**Legend**

Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.

N/A = Time Period not applicable to MPPCNV

Red = Noise Level Exceedance, project related

Blue = Noise level exceedance, not project related

~ = No Data Available

# = No contract work . Portable monitors are not being used (not needed).

**SR 520 Montlake Project**  
**Major Public Project Construction Noise Variance**  
**NOISE MONITORING - WEEKLY REPORT**  
**Monday, March 7, 2022 to Sunday, March 13, 2022 10 pm to 7 am (weekdays) / 9am (weekends)**

The table below includes data gathered from noise monitoring equipment located at seven stationary and three portable locations throughout the Montlake Project area

<b>Saturday, March 12, 2022</b>												
Site	Site limit*	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am
Site 1 -2449 E. Lk WA Blvd	67	53.4	50.9	47.3	45.8	44.7	43.9	46.6	50.6	52	53.5	53.0
Site 2 - 2015 E. Roanoke St	78	60.3	58.9	58	56.1	56.2	54.7	54.9	59	59.9	61	62.7
Site 3A - Canterbury Shores	62	52.6	51.4	49.4	47.4	46.9	46.0	44.0	49.4	52.2	52.2	54.7
Site 4 - 2800 Montlake Blvd E	66	65.9	63.8	62.5	62.1	65.0	59.8	61.2	65.4	64.8	65.8	67.0
Site 5 - 2565 22nd Av E.	65	58.9	57.6	56.3	55.0	54.6	53.5	53.3	57.5	58.3	59.5	61.0
Site 6 - 2160 E. Hamlin St	63	56.8	56.8	52.7	52.5	50.0	50.3	52.7	53.7	57.5	56.9	53.6
Site 7 - 2209 E. Lake Wa Blvd	66	52.6	50.3	48.1	46.8	46.1	44.1	46.4	49.7	51.6	52.4	52.5
Site 8 - Portable Between Sites 4 and 6	63	58.4	58.1	54.7	53.6	52.0	52.4	54.0	56.8	59.4	59.8	58.3
Site 9 - Portable Between Sites 1 and 7	66	61.7	59.3	58.5	58.3	58.4	56.3	56.4	59.5	60.1	61.4	62.7
Site 10 - Portable Between Sites 1 and 7	66	65.3	62.6	60.0	58.4	54.0	54.8	58.0	59.7	62.7	65.1	66.5

\*Hourly-Average Leq (dBA)

**Notes recorded by the on-site Independent Noise Monitor**

**Work:**

No nighttime construction work performed.

**Public Comments:**

No public comments received related to nighttime noise.

**Exceedances:**

Site(s) 4, & 10 exceedances are due to public traffic driving by the noise monitors (**not work related**).

**Non-Compliance:**

None

**Legend**

Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.

N/A = Time Period not applicable to MPPCNV

Red = Noise Level Exceedance, project related

Blue = Noise level exceedance, not project related

~ = No Data Available

# = No contract work . Portable monitors are not being used (not needed).



**SR 520 Montlake Project**  
**Major Public Project Construction Noise Variance**  
**NOISE MONITORING - WEEKLY REPORT**  
**Monday, March 7, 2022 to Sunday, March 13, 2022 10 pm to 7 am (weekdays) / 9am (weekends)**

The table below includes data gathered from noise monitoring equipment located at seven stationary and three portable locations throughout the Montlake Project area

<b>Sunday, March 13, 2022</b>												
Site	Site limit*	10pm - 11pm	11pm - 12am	12am - 1am	1am - 2am	2am - 3am	3am - 4am	4am - 5am	5am - 6am	6am - 7am	7am - 8am	8am - 9am
Site 1 -2449 E. Lk WA Blvd	67	45.2	51.1	44.0	42.0	39.8	46.0	50.4	51.9	54.9	N/A	N/A
Site 2 - 2015 E. Roanoke St	78	56.9	54.6	55.0	51.0	51.2	55.5	58.7	60.7	63.2	N/A	N/A
Site 3A - Canterbury Shores	62	50.0	46.6	45.3	42.6	41.6	45.5	49.5	51.8	53.8	N/A	N/A
Site 4 - 2800 Montlake Blvd E	66	63.0	60.3	58.5	57.5	57.9	62.4	65.7	68.7	69.8	N/A	N/A
Site 5 - 2565 22nd Av E.	65	55.6	53.8	55.0	50.2	49.8	53.8	57.0	59.3	61.8	N/A	N/A
Site 6 - 2160 E. Hamlin St	63	53.1	52.0	51.2	51.2	48.4	46.4	51.2	53.7	56.1	N/A	N/A
Site 7 - 2209 E. Lake Wa Blvd	66	46.3	44.8	44.2	42.1	43.2	46.2	49.6	52.0	54.3	N/A	N/A
Site 8 - Portable Between Sites 4 and 6	63	54.5	53.5	53.7	50.6	48.3	53.4	56.0	58.0	60.8	N/A	N/A
Site 9 - Portable Between Sites 1 and 7	66	57.9	55.8	55.8	52.2	52.5	57.4	59.5	62.7	65.4	N/A	N/A
Site 10 - Portable Between Sites 1 and 7	66	58.5	58.9	52.4	54.0	50.2	55.8	62.7	65.2	68.5	N/A	N/A

\*Hourly-Average Leq (dBA)

**Notes recorded by the on-site Independent Noise Monitor**

**Work:**

No nighttime construction work performed.

**Public Comments:**

No public comments received related to nighttime noise.

**Exceedances:**

Site(s) 4, 10 exceedance is due to public traffic driving by the noise monitors (**not work related**).

**Non-Compliance:**

None

**Legend**

Leq = Leq means the equivalent sound level, which is the constant sound level in a given time period.

N/A = Time Period not applicable to MPPCNV

Red = Noise Level Exceedance, project related

Blue = Noise level exceedance, not project related

~ = No Data Available

# = No contract work . Portable monitors are not being used (not needed).

**SR 520 Montlake Project**  
**Major Public Project Construction Noise Variance**  
**NOISE MONITORING - WEEKLY REPORT**  
 Monday, March 7, 2022 to Sunday, March 13, 2022      10 p.m. to 7 a.m. (weekdays)/9a.m. (weekends)

<b>Public Comment Log</b>			
<b>Date / Time</b>	<b>To/From</b>	<b>Issue</b>	<b>Resolution</b>
		No noise related complains	